

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/GH/2013/823

Dated: 26/02/2013

Certified that the **Asees inn - Guest House** located at F-50, Kirti Nagar, New Delhi., with 9 guest rooms + reception on ground floor & 9 guest rooms on first floor, of a four storied building was issued NOC vide this office letter No. **F6/DFS/MS/GH/10/132 dated 12/01/10**. The premises was re-inspected by the officers concerned of this department on **11/01/2013** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service Rule 2010 and the building/premises is fit for **Class-A-1 (i) Residential** occupancy with effect from 26/02/13.....for a period of three year in accordance with rule 36 unless renewed under 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under 38 of the Delhi Fire Service Rule 2010.

Issued on.....26/02/13.....at New Delhi by


26/2
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Sh. Rachneet Singh Bedi
Asees inn - Guest House located at F-50, Kirti Nagar, New Delhi
2. Addl Commissioner of Police (Lic.)
1st floor PS Defence Colony, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the means of escape shall be kept free of all type of obstruction all the time.
- 2) All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- 3) All the fire fighting equipment shall be maintained in perfect working condition all the time and lapse rendering non-functional of fire safety measures, management shall be responsible.
- 4) Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
- 5) Basement shall be used as per NBC.
- 6) This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no70106/Addl. C.P./Lic. (H) dated 12/12/2012 received from ACP of Police (Lic), regarding renewal of NOC in r/o Guest House in the name of Asees inn located at F-50, Kirti Nagar, New Delhi. Accordingly premises was inspected & observed that the building comprised ground floor & three upper floor. Fire safety arrangements are put up on the prescribed Performa.:

1. Name & address of the building : Asees inn - Guest House located at F-50, Kirti Nagar, New Delhi. (Located on G.F+F.F. only)
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/10/132 dated 12/01/2010
5. Fire Safety directives letter No. : nil
6. Date of inspection : 11.01.2013
7. Name of the Inspecting Officers : D.O. (MN)
8. Name and designation of officers
From the building side : Mr. Rachneet Singh Bedi
9. Year of Construction :
10. Applicant's letter No. : 70106/Addl. C.P./Lic. (H) dated 12/12/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	Old case	12 mtr	M.R.
	• Gate width	N.A.	N.A.	N.A
	• Width of internal road	N.A.	N.A.	N.A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Old case	1	M.R.
	• Upper Floors	Old case	1	M.R.
	• Basement	N.A.	N.A	N.A.

	b. Width of staircases			
	• Upper Floors	Old case	Old case	M.R.
	• Basement	N.A.	N.A.	N.A
	c. Protection of exits			
	• Fire check door	N.R.	N.R.	N.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	1	1	M.R.
		N.A.	N.A.	N.A
	e. Width of Corridor			
	f. Door size	1 mtr	1 mtr	M.R.
3.	Compartmentation.			
		N.A.	N.A.	N.A.
	• Fire check door	“ “	“ “	“ “
	• Sealing of electrical shafts	“ “	“ “	“ “
	• Fire Rating of shaft door	“ “	“ “	“ “
	• Water Curtain	“ “	“ “	“ “
	• Fire Dampers	“ “	“ “	“ “
4.	Smoke Management System.			
	• Basements	N.R.	N.R.	N.R.
	• Upper floors	“ “	“ “	“ “
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers 	06	10	M.R.
	<ul style="list-style-type: none"> Types 	ABC & CO ₂ type	provided	M.R.
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R.
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	required	1	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Location of Main Panel 	“ “	“ “	“ “
	<ul style="list-style-type: none"> Location of Repeater Panel 	“ “	“ “	“ “
	<ul style="list-style-type: none"> Alternate source of power 	“ “	“ “	“ “
	<ul style="list-style-type: none"> Hooter's Location 	“ “	“ “	“ “
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	Required	provided	M.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Upper Floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N.R.	N.R.	N.R.
11.	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Number of hydrants per floor 	“ “	“ “	“ “
	<ul style="list-style-type: none"> • Hose Box 	“ “	“ “	“ “
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Hose Box 	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	Old case	220 LPM	M.R.
	➤ Head of the pump	Old case	30 mtr	M.R.


11-9

<ul style="list-style-type: none"> ➤ Power supply ➤ Auto Starting of pump 	<p>Old case R M</p>	<p>Provided</p>	<p>M.R.</p>
	<p>manual. Old case M</p>	<p>manual</p>	<p>M.R.</p>
<p>14. Captive Water Storage for fire fighting.</p>			
<p>Underground tank capacity</p> <ul style="list-style-type: none"> ➤ Draw -off connection ➤ Fire service inlet ➤ Access to tank ➤ Overhead Tank Capacity 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
	<p>Old case M</p>	<p>4000ltr</p>	<p>M.R.</p>
<p>15. Exit Signage.</p>	<p>Old case R</p>	<p>5,000 ltr Provided</p>	<p>M.R.</p>
<p>16. Provision of Lifts</p>			
<ul style="list-style-type: none"> • Pressurization of Lift Shaft 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<ul style="list-style-type: none"> • Pressurization of Lift lobby 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<ul style="list-style-type: none"> • Communication In lift Car 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<ul style="list-style-type: none"> • Fireman's Grounding Switch 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<ul style="list-style-type: none"> • Lift Signage 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<p>17. Standby power supply</p>	<p>Old case N.R.</p>	<p>N.R.</p>	<p>M.R. N.R.</p>
<p>18. Refuge Area</p>			
<ul style="list-style-type: none"> ➤ Total Area 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>
<ul style="list-style-type: none"> ➤ Location 	<p>N.R.</p>	<p>N.R.</p>	<p>N.R.</p>

N-10

19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R ✓
	➤ Flow Switch Panel	N.R	N.R	N.R ✓
	➤ PA system Panel	N.R	N.R	N.R
	➤ Batter backuplk	N.R	N.R	N.R ✓
	➤ Building Floor plans	N.R	N.R	N.R ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O.

Designation

sunil chowdhary