

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE: NEW DELHI-110001


No.F.6/DFS/MS/2013/ 820

Dated: 26/02/2013

FIRE SAFETY CERTIFICATE

Certified that Sant Nirankari Public School, Sant Nirankari Colony, Delhi-9 located at Nirankari Colony comprised of ground plus two upper floors occupied by Sant Nirankari Public School was issued NOC vide this officer letter No. F.6/DFS/MS/08/1199 dated 25.04.08. The premises was re-inspected by the officer concerned of this department on 26.10.12 and observed that two rooms have been added on the terrace and all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular 262-362 dated 17.01.05 and the building / premises is fit for occupancy Class Educational with effect from....26/2/13... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010.

Issued on 26/2/13 at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to:

- (1) The Prinicpal
Sant Nirankari Public School
Nirankari Colony, Delhi-9.
- (2) The Director of Education
Old Secretariat, Delhi.


Jc
Resd
26/2/13

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building Sant Nirankari Public School, Nirankari Colony, Delhi-9
2. Type of Occupancy: Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFC/MS/08/1199 Dated: 25-4-2008
5. Fire Safety directives letter No : Circular, Director of Edm. 17-1-2005.
6. Date of inspection: 26-10-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers Smt. Poonam Syal (Principal)
from the building side :
9. Year of Construction: 1989 (G+2) 2010 (two room on Terrace.
10. Applicant's letter No. : Nil dated 18-9-2012

Sl. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edm. 17-1-05 Requirement	Provided at site	Remarks MR/NMR
1	Access to building	(Old Case)		
	• Road width	Accessible	9 m	M/R
	• Gate width	-do-	4.68 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	M/R
	• Basements	Nil	Nil	Nil
	b. Width of staircases			
	• Upper Floors	1.5 m	1.27m & 1.30m	old case M/R
	• Basements	Nil	Nil	Nil
	c. Protection of exits			
	• Fire check door	N/R	N/P	N/A
	• Pressurization	N/R	N/P	N/A
	e. No. of continuous staircases to terrace	2	2	M/R
	g. Width of Corridor	R	2.32 m	M/R
	h. Door Size	1 m	1.15 m	M/R

3	Compartmentation.			
	• Fire check door	N/R	N/P	N/A
	• Sealing of electrical shafts	N/R	N/P	N/A
	• Fire Rating of shaft door	N/R	N/P	N/A
	• Water Curtain	N/R	N/P	N/A
	• Fire Dampers	N/R	N/P	N/A
4	Smoke Management System.			
	• Basements	30 a/c per hour	N/R	N/A
	• Upper floors	12 a/c per hour	N/R	N/A
5	Fire Extinguishers			
	• Total numbers	09	09	MIR
	• Types	ABC or CO2 (25kg)	ABC	MIR
	• IS marking	ISI marked	yes	MIR
6	First-Aid Hose Reels.			
	• Total numbers on each floor	Two	Two	MIR
	• Length of hose reel hose	30 m	Provided	MIR
	• Nozzle diameter	5 mm	Provided	MIR
7	Automatic fire detection and alarming system.			
	• Type of detectors	N/R	N/P	N/A
	• Location of Main Panel	N/R	N/P	N/A
	• Location of Repeater Panel	N/R	N/P	N/A
	• Alternate source of power	N/R	N/P	N/A
	• Hooters' Location	N/R	N/P	N/A
8	MOEFA	N/R	N/P	N/A
9	Public Address System.	N/R	N/P	N/A
10	Automatic Sprinkler System.			
	• Basement	N/R	N/P	N/A

	<ul style="list-style-type: none"> Upper Floor 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	N/R	N/P	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	100 mm	MIR
	<ul style="list-style-type: none"> Number of hydrants per floor 	one	one	MIR
	<ul style="list-style-type: none"> Hose Box 	one	one	MIR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Hose Box 	N/R	N/P	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/R	N/P	N/A
	<ul style="list-style-type: none"> Terrace level 			
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450 Lts./min	provided	MIR
	<ul style="list-style-type: none"> ➤ Head of the pump 	40 m	provided.	MIR
	<ul style="list-style-type: none"> ➤ Power Supply 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	R	provided	MIR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	N/R	N/P	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	N/R	N/P	N/A

	➤ Fire service inlet	N/R	N/P	N/A
	➤ Access to tank	N/R	N/P	N/A
	• Overhead Tank capacity	5000 Lts.	5000 Lts	N/A (old case)
15	Exit Signage.	R	Provided	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/R	N/P	N/A
	• Pressurization of Lift lobby	N/R	N/P	N/A
	• Communication In lift Car	N/R	N/P	N/A
	• Fireman's Grounding Switch	N/R	N/P	N/A
	• Lift Signage	N/R	N/P	N/A
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area	N/R	N/P	N/P
	➤ Location	N/R	N/P	N/P
19	Fire Control Room			
	• Detector System Panel	N/R	N/P	N/A
	• Flow Switch Panel	N/R	N/P	N/A
	• PA System Panel	N/R	N/P	N/A
	• Batter backup	N/R	N/P	N/A
	• Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....