

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013 /867

Dated: 01 / 03 /2013

FIRE SAFETY CERTIFICATE

Certified that the Invitation Banquet, B-12 C.T.K. Rd. Ind. Area Delhi comprised of Basement Ground + Two upper floors with Basement for Services, Ground and first floor for Banquet hall, second floor for office & kitchen.....owned/occupied by Invitation Banquet.....have complied with fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of fire service on 18/2/2013.....in the presence of Sh. Subhash Kakkar (Partner).....and that the building /premises is fit for occupancy Assembly (Banquet).....building with effect fromfor period of Three years.....in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....at New Delhi.


Chief Fire officer

Delhi Fire Service

07c M

Copy to:-

1. The Dy. Health Officer
Civil Line Zone North M.C.D
16, Raj Park Road Delhi
2. Sh. Subhash Kakkar (Partner)
Invitation Banquet, B-12 C.T.K. Rd.
Ind. Area Delhi

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non - functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

2/11

INSPECTION REPORT

1. Name & address of the building : Invitation Banquet, B-12 G.T.K. Rd Ind. Area Delhi
2. Type of Occupancy : Assembly Bldg. (Banquet Hall) Basement - Services.
G.F. & F.F - Banquet hall.
1st floor - office & kitchen
3. Type of Case : New Case/ Renewal (Old Bldg.)
4. Details of previous NOC : Letter No. N/A Dated: -
5. Fire Safety directives letter No : F-6/285/MS/2012/131/2201 dt-3/5/12
6. Date of inspection : 18/2/13
7. Name of the Inspecting Officers : Deto Vign Kental
8. Name and designation of officers from the building side : Sh. Subhash Karkhan
9. Year of Construction : 2010
10. Applicant's letter No. : 7-1-13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr.	18 mtr.	M/R
	• Gate width	N.A	-	-
	• Width of internal road	To be checked by Bldg. Dept.		
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	M/R
	• Basements	02	02	M/R
	b. Width of staircases			
	• Upper Floors	1.5 mtr.	provided	M/R
	• Basements	1.5 mtr	provided	M/R
	c. Protection of exits			
	• Fire check door	R	P	M/R.
	• Pressurization	N/A	-	-
	e. No. of continuous staircases to terrace	-	-	-
	g. Width of Corridor	-	-	-
	h. Door Size	02 mtr	P	M/R
3	Compartmentation.			
	• Fire check door	R	P	M/R
	• Sealing of electrical shafts	No Elect. shafts inside the Bldg.		
	• Fire Rating of shaft door	-	-	-
	• Water Curtain	N/A	-	-
	• Fire Dampers	N/A	-	-
4	Smoke Management System.			
	• Basements	30 a/c per hour	P	M/R
	• Upper floors	12 a/c per hour	P	M/R

M13

14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50000 Ltr.	P	MIR
	➤ Draw-off connection	R	P	MIR
	➤ Fire service inlet	R	P	MIR
	➤ Access to tank	R	P	MIR
	• Overhead Tank capacity	10000 Ltr.	P	MIR
15	Exit Signage.	R	P	MIR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N.A	-	-
	• Pressurization of Lift lobby	-	-	-
	• Communication In lift Car	R	P	MIR
	• Fireman's Grounding Switch	R	P	MIR
	• Lift Signage	R	P	MIR
17	Standby power supply	R	P	MIR
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	• Detector System Panel	R	P	MIR
	• Flow Switch Panel	-	-	-
	• PA System Panel	R	P	MIR
	• Batter backup	R	P	MIR
	• Building Floor Plans	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	-	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

C.F.O. [Signature] 2-12

[Signature] 19/2

F.T. M.S. Cell