

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001


No: F.6/DFS/MS/2013/ *School/843*

Dated: *28/02/13*

FIRE SAFETY CERTIFICATE

Certified that the - **Vikas Valley Public School, S-11.12.13 S -Block, New Delhi- 110059** Comprised of - ground floor plus one upper floor, having 22 rooms (Including Class rooms, offices, Library, Multi Media & computer room) and owned/occupied by Vikas Valley Public School. The school building was inspected by the officer concerned of this department on 23.01.2013 in the presence of Sh. Sameer Arora, Principal and found that the school management have complied with the fire prevention and fire safety requirement in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/premises is fit for occupancy class - group-B (Educational) with effect from the date of issue of this certificate for a period of a three years. Subject to compliance of the conditions printed overleaf.

Issued on *28/02/13* .....at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal,  
Vikas Valley Public School,  
S-1112, 13 S-Blocks, Vikas Nagar,  
New Delhi-110059
2. The Director of Education  
Govt. of N.C.T. of Delhi,  
Old Secretariat, Delhi.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**INSPECTION REPORT**

1. Name & address of the building : Vikas Valley Public School, S-11, 2, 13, S-Block
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: —
5. Fire Safety directives letter No : NIL
6. Date of inspection : 23/1/13
7. Name of the Inspecting Officers : H. L. ANEJA (DO)
8. Name and designation of officers from the building side : Mr Sameer Arora - Principal
9. Year of Construction : —
10. Applicant's letter No. : NIL dt 14/11/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	R	6 Mtrs	MR
	• Gate width	R	310 Mtrs	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	b. Width of staircases	R	150 cms & 114 cms	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	c. Protection of exits	NR	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	— Nos —	MR
	g. Width of Corridor	R	130 cms	MR
	h. Door Size	R	100 cms	MR

3	<b>Compartmentation.</b>						
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	NR					
4	<b>Smoke Management System.</b>						
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	NR	30 a/c per hour				
			12 a/c per hour				
5	<b>Fire Extinguishers</b>						
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	R	ISI marked	P	6 Nos	MR	
					DCP type		
					Yes		
6	<b>First-Aid Hose Reels.</b>						
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	NR	30 m				
			5 mm				
7	<b>Automatic fire detection and alarming system.</b>						
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>	NR					
8	<b>MOEFA</b>						
9	<b>Public Address System.</b>						
10	<b>Automatic Sprinkler System.</b>						
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	NR					

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	—	—	—
11	<b>Internal Hydrants</b>	HR	—	—
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>	—	—	—
12	<b>Yard Hydrants.</b>	HR	—	—
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>	—	—	—
13	<b>Pumping Arrangements.</b>	HR	—	—
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	—	—	—
14	<b>Captive Water Storage for fire fighting.</b>	HR	—	—
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>	—	—	—

MM

	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity			
15	<b>Exit Signage.</b>	NR		
16	<b>Provision of Lifts.</b>	NR		
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication In lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	<b>Standby power supply</b>	NR		
18	<b>Refuge Area.</b>	NR		
	➤ Total Area			
	➤ Location			
19	<b>Fire Control Room</b>	NR		
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Batter backup			
	• Building Floor Plans			
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>	NR		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ ..... NMC .....

*H. L. Anreja*

Signature of the Inspecting Officer

Name *H. L. ANEJA*

Designation *Div Officer.*

Signature of the Inspecting Officer

Name

Designation

5