

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE:NEW DELHI- 110 001

No. F6/DFS/MS/AW/2013/06

Dated 05/03/13

FIRE SAFETY CERTIFICATE

Certified that the Sh. Akshay Jain Shop No. 3,D -29, Kh. No. 446, Dayanand Block, Shakar Pur, Delhi comprises of ground floor only have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of Fire Service on dated 16-2-2013 in the presence of Mr. Akshay Jain & Inderver Jain and that the building is fit for occupancy class Fireworks storage with effect from 05/03/13 for a period of three years, subject to conditions printed overleaf.

Issued on 05/03/13 at New Delhi by



Chief Fire Officer
Delhi Fire Service

To,

The Additional Commissioner of police (Licensing),
1st Floor, P.S. Defence colony, New Delhi.

Copy to:-

Sh. Akshay Jain Shop No. 3,D -29,
Kh. No. 446, Dayanand Block,
Shakar Pur, Delhi

05/03/13
01.3.2013

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention and safety measures provided in the Building/premises are in good working condition.

INSPECTION REPORT

- 1. Name & address of the building : SH. Akshay Jain, shop No 3, D-29, Kh. No. 446, Dayanand Block, Shakarpur, Delhi-92.
- 2. Type of Occupancy : Storage / Sale of fire crackers.
- 3. Type of Case : New case.
- 4. Details of Previous NOC : N.A.
- 5. Fire Safety direction letter No : N.A.
- 6. Date of Inspection : 16.2.2013
- 7. Name of the Inspecting Officers : Gurmukh Singh.
- 8. Name of the Person from the Building side : SH. Indarveer Jain & SH. Akshay Jain.
- 9. Year of Construction : 1965 (Tentatively)
- 10. Reference/Licensing deptt. letter no. : (PFW/02)/2013/6019-22 / Addl. CP/Dic. (Expt.) dt. 8/2/13.


S.NO.	Point of Inspection	Requirement	At Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m ²	15 m ²	MR
	b. Construction	Pucca	Pucca	MR
	c. Premises Location	Gr. Fl.	Gr. Floor	MR
	d. Business permissible only at ground floor level	Gr. Fl.	Gr. Floor.	MR
	e. Business from pavement of road prohibited	Inside Shop	Inside Shop	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Reqd.	Available	MR

- 11/2 -

3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/ inflammable or hazardous materials.	Regd.	Available Presently.	MR.
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	Shop Vacant Presently.	MR.
5.	Type of electrical wiring and electrical fittings			
	a. Preferably concealed or through conduit	Regd.	concealed Type.	MR.
	b. All electrical fitting should be flame/spark proof	Regd.	Provided.	MR.
6	Extension of Shop for Business.			
	Prohibited	Prohibited	NO extn. observed.	MR.
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 mtr.	13 mtr.	MR.
8	Fire Protection Arrangement.			
	a) Extinguishers (Type & No's.)	CO ₂ & ABC Type	1 CO ₂ & 3 ABC Type Provided.	MR.
	b) Sand and Water Buckets	2 Buckets	04 Buckets	MR.
	c) Water Drum(s)	Regd.	200 lbs. option Provided.	MR.
9	Any other point that is contrary to the safety of people.		"NO SMOKING" sign board seen.	

The fire protection systems provided in shop were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.


 Signature of the Inspecting Officer
 Name GURMUKH SINGH.
 ADO(M)

DO(E) Submitted please.