

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2013/ 10

Dated: 05/03/2013

FIRE SAFETY CERTIFICATE

Certified that **Mayank Plaza Guest House located at 7864, Arakashan Road, Paharganj, New Delhi** comprised of ground floor (Reception + 01 guest room), first floor (02 guest rooms), second floor (02 guest rooms) & third floor (02 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/2582 dated 20-08-2009. The premise was re-inspected by the officer concerned of this department on 27-02-2013 in the presence of Mr. Deepak Bawa, owner of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 05/03/13 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on 05/03/13 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi w.r.t. your letter No.57575-76/Addl.C.P./Lic(H) dated 01-10-2012.
2. The Manager, Mayank Plaza Guest House, 7864, Arakashan Road, Paharganj, New Delhi.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

old case

INSPECTION REPORT

1. Name & address of the building : Mayank Plaza Guest House, 7864, Arakashan Road, Paharganj, New Delhi
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F.6/DFS/MS/GH/2009/2582 Dated: 20-08-2009
5. Fire Safety directives letter No : N/A
6. Date of inspection : 27-02-2013
7. Name of the Inspecting Officers : M.K. Chattopadhyay, ADO (CC)
8. Name and designation of officers
from the building side : Deepak Bawa, Owner
9. Year of Construction : 2001
10. Applicant's letter No. : 57575-76/Addl.C.P./Lic(H) Dated: 01-10-2012.


S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Spl. Area	More than 06 mts.	MR
		-	Directly accessible from the road	MR
		N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	01	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-	-	-
	• Upper Floors	0.80 mts	71-80 mts	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits	N/A	N/A	-----
	• Fire check door	N/A	N/A	-----
	• Pressurization	N/A	N/A	-----
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
		N/A	N/A	-----

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Water Curtain 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Fire Dampers 	N/A	N/A	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	30 a/c per hour	N/A	N/A
	<ul style="list-style-type: none"> • Upper floors 	12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 	08	Provided	MR
	<ul style="list-style-type: none"> • Types 	Water CO ₂ , CO ₂	Provided	MR
	<ul style="list-style-type: none"> • IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor 	-----	N/A	N/A
	<ul style="list-style-type: none"> • Length of hose reel hose 	30 m	N/A	N/A
	<ul style="list-style-type: none"> • Nozzle diameter 	5 mm	N/A	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Location of Main Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Location of Repeater Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Alternate source of power 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Hooters' Location 	N/A	N/A	-----
8	MOEFA	N/A	N/A	N/A
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Upper Floor 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	N/A	N/A	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	N/A	N/A	-----

	<ul style="list-style-type: none"> • Communication In lift Car 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Fireman's Grounding Switch 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Lift Signage 	N/A	N/A	-----
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Flow Switch Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	01 CO ₂ type fire extinguisher provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name M.K.CHATTOPADHYAY
 Designation :- Asstt. Div. Officer (CC)

Forwarded pl.
 28-2-13
 (CD)