

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013/53

Dated: 12/03/13

FIRE SAFETY CERTIFICATE

Certified that the M/s Laxmi Ice and Cold Storage Located at 7652/1, G T Karnal Road, Subzi Mandi, Delhi-110007 comprised of Ground floor only has already been issued Fire Safety Certificate for running trade of Ice Factory vide this office letter No F-5/(J)/DFS/2008/81 Dated 13/02/2008. The premise have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concern of Fire Service on 07/02/2013 in presence of Mr Rajesh Yadav (Manager) of the Factory and that the premise is fit for Class G (G-1) Industrial occupancy with effect from 12/03/13 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 12/03/13 at New Delhi by


Chief Fire Officer
Delhi Fire Service



Copy to:

1. M/s Laxmi Ice and Cold Storage, 7652/1, G T Karnal Road, Subzi Mandi, Delhi-110007
2. Dy Health Officer, North Delhi Municipal Corporation, Civil Line Zone, 16, Rajpur Road, Delhi-110054

2/7

INSPECTION REPORT

- 1. Name & address of the building : M/s Laxmi Ice & Cold Storage, 7652/1, G.T.K. Rd. Bhisla Line old Subzi Mandi Delhi 11007.
- 2. Type of Occupancy : Ice factory (G-1)
- 3. Type of Case : New Case/ Renewal
- 4. Details of previous NOC : Letter No. F.5/(J)/Dfs/2008/A1 Dated: 13/2/2008
- 5. Fire Safety directives letter No : -
- 6. Date of inspection : 7/2/2013
- 7. Name of the Inspecting Officers : DO (NW) S.S. Tuli
- 8. Name and designation of officers from the building side : Sh. Rakesh Yadav (Manager)
- 9. Year of Construction : 1957 (single storied)
- 10. Applicant's letter No. : H/D DHO/CL2/2013/2016 dt- 4/1/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Motorable Road</u>		<u>M/R</u>
	• Gate width	<u>-</u>	<u>-</u>	<u>-</u>
	• Width of internal road	<u>-</u>	<u>-</u>	<u>-</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases	<u>NA</u>		
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size			
3	Compartmentation.			
	• Fire check door			
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		

18

MM

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	6 NBS	2 N ₂ , 2 ABC, 2 CO ₂	MIR
		ISI marked	yes	MIR
			yes	MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	R	provided	MIR
		30 m	P	MIR
		5 mm	P	MIR
7	Automatic fire detection and alarming system.		N/R	
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA		N/R	
9	Public Address System.			
10	Automatic Sprinkler System.		N/R	
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/R		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/R		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	450 lpm	provided	MIR
		40mtr		MIR

N/P

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A		
15	Exit Signage.	5000 ltrs. provided	Regd P	M/R
16	Provision of Lifts.	N/A		
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A		
17	Standby power supply	N/A		
18	Refuge Area.	N/A		
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A		
19	Fire Control Room	N/A		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A		
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A		

- ✓ The fire protection systems provided in the building were test checked and found functional at the time of inspection.
- ✓ Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....X.....

Signature of the Inspecting Officer
 Name: *[Signature]*
 Designation: *SS Tuli Do (NW)*

Signature of the Inspecting Officer
 Name: *[Signature]*
 Designation: *Do (NW)*