

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001

NO. F.6/DFS/MS/Cinema/2013/51

DATED: 08/03/13

FIRE SAFETY CERTIFICATE

Certified that the Gianand Cinema at G.T. Road, Shahdara, Delhi, owned/occupied by Gianand Cinema, comprising of ground plus mezzanine only was granted NOC vide letter no. No.F.6/DFS/MS/Cinema/2011/2002 dated 17.08.11. The Cinema building was inspected by the officers concerned of this department on dated 25.02.13 in the presence of joint inspection team along with Mr. Mohan Lal Jain (Manager) and found that the Cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D "Assembly Building" with effect from ...08/03/13... for a period of three years, subject to conditions printed overleaf.

Issued on ...08/03/13... at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

To.

Sh.Mohan Lal Jain,  
Gianand Cinema,  
G.T. Road, Shahdara, Delhi.

Copy to:-

The Addl. Commissioner of Police (Lic.),

First Floor, Police Station,  
Defence Colony, New Delhi.

In reference letter no.6924-27/ Addl.CP/Lic. Cinema

Dated 13.02.13

  
JC  
Red  
7-3-13

- Conditions -

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

**FIRE SAFETY INSPECTION REPORT**

Sl. No.	APPLIANCES	AVAILABILITY	CONDITION
a.	Overhead/ Underground tank	15000	
b.	No. of Hydrants	1	
c.	No. of Hose Reels	3	
d.	Number of Fire buckets of sand & water: 1) Main Hall 2) Balcony 3) Box 4) Projector Room 5) Elect. Sub-Station 6) Rectifier Room 7) AC Plant Room 8) Any others	6 No 2 No	
e.	Number of portable fire extinguishers 1) Main Hall 2) Balcony 3) Box 4) Projector Room 5) Elect. Sub-Station 6) Rectifier Room 7) AC Plant Room 8) Any others	4 3 2 2 1 Swiped roo	
f.	Number of fire extinguishers for Projector Room.	2 No	
g.	No. of Lightening conductors	Provided	
h.	Fire alarm system	Provided	
i.	Sprinkler system	N/A	
j.	Escape and exit routes: PRSENT	REQUIREMENT	ANY SUGGESTION/ SHORTCOMINGS
		Adequate as required	

II.	Name of trained staff of cinema hall in handling fire safety equipments	Level of Training
a.	Chitranjan Singh	Basic.
b.	Mitai Lal	Basic
c.	Rakesh	Basic
d.		

III.	Any other comments.
------	---------------------

Name and designation of the Inspection Officer Suresh Singh A.P.P.

Suresh Singh  
Signature

Telephone Number (Office) 22513330 (Mobile) 9911151733

Defects/Shortcomings noted for compliance