

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001


No. F6/DFS/MS/School/2013/ 57

Dated: 13/03/13

FIRE SAFETY CERTIFICATE

Certified that the **Govt. Girl Sec. School, J.J.Colony, Madanpur Khadar Extn., New Delhi (School ID-1925340)**, comprised of ground floor **Owned/Occupied** by Govt. Girl Sec. School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 20/02/2013 in the presence of Mrs. Navina Srivastava of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 13/03/13 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 13/03/13 at New Delhi by


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy To: -

1. The Directorate of Education, Govt. of NCTD, Old Secretariat, New Delhi.
2. The Principal, Govt. Girl Sec. School, J.J.Colony, Madanpur Khadar Extn., **New Delhi**

Conditions for the validity of Fire Safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

School ID- 1925 340

1. Name and address of the building : Gaut. Girls Sec. School.
: J.J. Colony, Madanpur Kheda Bet. ND-76
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety Directives letter No : Slip of Edn Circular dated 01/3/11
6. Date of Inspection : 20/02/2013
7. Name of the Inspecting Officer : Dharampal Bhavadraaj, Do(South)
8. Name and designation of the Officers from the building side : Mrs Navina Srivastava, Incharge
9. Year of Construction : 2005 (Ground floor only)
10. Applicant's letter No. : Nil

| S. No. | Minimum Standards on Fire Prevention and Fire Safety U/R 33 | NBC Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|------------------|----------------|
| 1 | Access to building | | | |
| | • Road width | Accessible | 6 Mts | MR |
| | • Gate width | NA | 5 Mts | MR |
| | • Width of internal road | NA | NA | NA |
| 2 | Number, Width, Type & Arrangement of Exits | | | |
| | • Number of Staircase | | NA | |
| | ➤ Upper floors | | | |
| | ➤ Basement | | | |
| | • Width of Staircase | | NA | |
| | ➤ Upper floors | | | |
| | ➤ Basement | | | |
| | • Protection of Exits | | NA | |
| | ➤ Upper floors | | | |
| | ➤ Basement | | | |
| | • No of Continuous Staircases to terrace | NA | NA | NA |
| | • Width of Corridor | NA | NA | NA |
| | • Door Size | 1.0 Mts | 1.0 Mts | MR |

| | | | | |
|-----------|---|--|---------------------|----------------|
| 3 | Compartmentation | NA | | |
| | <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers | | | |
| 4 | Smoke Management System | NA | | |
| | <ul style="list-style-type: none"> • Basements • Upper Floors | | | |
| 5 | Fire Extinguishers | | | |
| | <ul style="list-style-type: none"> • Total Number • Types • IS marking | <u>0m / 300 m²</u> ABC / CO2 ISI mark | 8 Nos ABC YES | MR MR MR |
| 6 | First-Aid Hose Reels | NA | | |
| | <ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter | _____/Per Floor 30 m 5mm | | |
| 7 | Automatic Fire Detection and Alarming System | NA | | |
| | <ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location | | | |
| 8 | MOEFA | NA | | |
| 9 | Public Address System | NA | | |
| 10 | Automatic Sprinkler System | NA | | |
| | <ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling | | | |
| 11 | Internal Hydrant | NA | | |
| | <ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box | | | |
| 12 | Yard Hydrant | NA | | |
| | <ul style="list-style-type: none"> • Total Number of hydrants • Hose Box | | | |

| | | | | |
|-----------|--|----|--|--|
| 13 | Pumping Arrangements | NA | | |
| | Ground Level | | | |
| | ➤ Number of main pump | | | |
| | ➤ Discharge of main pump | | | |
| | ➤ Head of main pump | | | |
| | ➤ Jockey pump out put | | | |
| | ➤ Jockey pump Head | | | |
| | ➤ Standby pump out put | | | |
| | ➤ Standby Pump Head | | | |
| | ➤ Auto Starting/Manual stopping | | | |
| | ➤ Pump House Access | | | |
| | Terrace level | NA | | |
| | ➤ Discharge of pump | | | |
| | ➤ Head of the pump | | | |
| | ➤ Power Supply | | | |
| | ➤ Auto starting /Manual stopping | | | |
| 14 | Captive Water Storage for Fire Fighting | NA | | |
| | • Underground tank capacity | | | |
| | ➤ Draw-off connection | | | |
| | ➤ Fire service inlet | | | |
| | ➤ Access to tank | | | |
| | • Overhead tank capacity | | | |
| 15 | Exit Signage | NA | | |
| 16 | Provision of Lifts | NA | | |
| | • Pressurization of Lift Shaft | | | |
| | • Pressurization of Lift lobby | | | |
| | • Communication in lift Car | | | |
| | • Fireman's Grounding Switch | | | |
| | • Lift Signage | | | |
| 17 | Standby Power Supply | NA | | |
| 18 | Refuge Area | NA | | |
| | • Total Area | | | |
| | • Location | | | |
| 19 | Fire Control Room | NA | | |
| | • Detector System Panel | | | |
| | • Flow Switch Panel | | | |
| | • PA System Panel | | | |
| | • Battery back up | | | |
| | • Building Floor Plans | | | |


| | | | | |
|----|---|----|----|----|
| 20 | Special Fire Protection System for Protection of special risk, if any | NA | NA | NA |
|----|---|----|----|----|

The Fire protection systems provided in the building were test checked and found functional / non-functional at the time of inspection.

Keeping in view the substantial / insubstantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number.~~

Accordingly, DFA / FT letter is put up for perusal & approval please.

Dy. Cfo. Sachin A. H. 598


4/8/13
Signature of Inspecting Officer
Name: Dharampall Bharadwaj
Designation: DIV. OFFICER