

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2013/56

Dated: 13/03/13

FIRE SAFETY CERTIFICATE

Certified that the **M.C. Primary School, Bharat Nagar (Boys), D-Block, New Friends Colony, New Delhi**, comprised of ground floor only **Owned/Occupied** by M.C Primary School has complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 19/02/2013 in the presence of Sh. Izhar Alam, Head Master of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 13/03/13 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 13/03/13 at New Delhi by


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy To: -

1. The Directorate of Education, Govt. of NCTD, Old Secretariat, New Delhi.
2. The Principal M.C. Primary School, Bharat Nagar (Boys), D-Block, New Friends Colony, New Delhi

Conditions for the validity of fire safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M. C. PRIMARY SCHOOL
 : BHARAT NAGAR (Boys)
 : D-Block, New Friends Colony, ND-25
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : NIL Dt. -
5. Fire Safety Directives letter No : Dir of Edn Circular Dt. 01/3/2011
6. Date of Inspection : 19/02/2012
7. Name of the Inspecting Officer : Dharampal Bhavadwoj 20(South)
8. Name and designation of the Officers from the building side : Shri Izhar Alam, Head Master
9. Year of Construction : 1980 (Ground floor only)
10. Applicant's letter No : NIL

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	9 mts	MR
	• Gate width	NA	4 mts	MR
	• Width of internal road	NA	NA	MR
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase		NA	
	➤ Upper floors			
	➤ Basement			
	• Width of Staircase		NA	
	➤ Upper floors			
	➤ Basement			
	Protection of Exits		NA	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size / Width	1.0 mts	1.10 & 1.0 mts	MR

3	Compartmentation			NA
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System			NA
	<ul style="list-style-type: none"> • Basements • Upper Floors 			
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	<u>One / 300 m²</u> ABC / CO2 ISI mark	4 Nos ABC YES	MR MR MR
6	First-Aid Hose Reels			NA
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	_____/Per Floor 30 m 5mm		
7	Automatic Fire Detection and Alarming System			NA
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 			
8	MOEFA / SIRON		Required	Provided MR
9	Public Address System		NA	NA NA
10	Automatic Sprinkler System			NA
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 			
11	Internal Hydrant			NA
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 			
12	Yard Hydrant			NA
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 			

13	Pumping Arrangements			
	Ground Level		NA	
	➤ Number of main pump			
	➤ Discharge of main pump			
	➤ Head of main pump			
	➤ Jockey pump out put			
	➤ Jockey pump Head			
	➤ Standby pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	Terrace level		NA	
	➤ Discharge of pump			
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto starting /Manual stopping			
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	NA	10,000 Lts	MR
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead tank capacity	NA	NA	NA
15	Exit Signage	NA	NA	NA
16	Provision of Lifts		NA	
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply	NA	NA	NA
18	Refuge Area		NA	
	• Total Area			
	• Location			
19	Fire Control Room		NA	
	• Detector System Panel			
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional / ~~non-functional~~ at the time of inspection.

Keeping in view the substantial / ~~insubstantial~~ compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number~~.....

Accordingly, DFA / FT letter is put up for perusal & approval please.

Dy CPO - South
[Signature]

[Signature]
 4/8/13
Signature of Inspecting Officer
Name: Dharampal Bharadwaj
Designation: DIV. OFFICER