

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,  
NEW DELHI-110001**

No. F6/MS/DFS/GH/2013/60

Dated: 13/03/13

**FIRE SAFETY CERTIFICATE**

Certified that the Narain Lodge Guest House, 8597-98, Desh Bandu Gupta Road, Pahar Ganj, New Delhi-110055 comprised of basement (closed), ground floor (05 guest rooms + reception), 1<sup>st</sup> floor (04 guest rooms), 2<sup>nd</sup> floor (02 guest rooms), terrace (staff kitchen), total 11 guest rooms, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2010/328 dated 03-02-2010. The premises was re-inspected by the officer concerned of this department on 07-03-2013 in the presence of Mr. Jaswinder Pal (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 11 guest rooms with effect from 13/03/2013 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 13/03/13 at New Delhi by.



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE



Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.68336/Addl.C.P./Lic.(H) New Delhi dated 03-12-12.
2. M/s Narain Lodge Guest House, 8597-98, Desh Bandu Gupta Road, Pahar Ganj, New Delhi- 110055.

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

**INSPECTION REPORT**

1. Name & address of the building : Narain Lodge Guest House, 8597-98, Desh Bandu Gupta Road, Pahar Ganj, New Delhi-110055
2. Type of Occupancy : Lodging House
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/GH/2010/328 dated 03-02-2010
5. Fire Safety directives Letter No. : N/A
6. Date of inspection : 07-03-2013
7. Name of the Inspecting Officer : Sh. D.S. Yadav (D.O.) & M. K. Chattopadhyay (A.D. O.)
8. Name and designation of Officer from the building side : Mr. Jaswinder Pal (owner)
9. Year of Construction : 2009 Starting Year
10. Applicant's letter No. : 68336/Addl.C.P./Lic.(H) dated New Delhi the 03-12-2012

| S No | Minimum standards on fire prevention and fire safety U/R 33 | BBL Requirements | Provided at site (PSS Area) | Remarks MR/NMR (Old Case) |
|------|---|------------------|-----------------------------|---------------------------|
| 1.   | Access of building  |                  |                             |                           |
|      | • Road width  | N/A              | 6 mtrs. Approx.             | MR                        |
|      | • Gate width  | N/A              | N/A                         | N/A                       |
|      | • Width of internal road                                    | N/A              | N/A                         | N/A                       |
| 2.   | Number, width, Type & Arrangements of exits                 |                  |                             |                           |
|      | a. Number of staircases                                     |                  |                             |                           |
|      | • Upper floors  | 01               | 01                          | MR                        |
|      | • Basements   | N/A              | N/A                         | N/A                       |
|      | b. Width of staircases                                      |                  |                             |                           |
|      | • Upper floors  | 80 cms           | 90 cms. to 120 cms.         | MR                        |
|      | • Basements   | N/A              | N/A                         | N/A                       |
|      | c. Protection of exits                                      |                  |                             |                           |
|      | • Fire check door   | N/A              | N/A                         | N/A                       |
|      | • Pressurization  | N/A              | N/A                         | N/A                       |
|      | d. No of continuous staircase to terrace                    | 01               | 01                          | MR                        |
|      | e. Width Of Corridor  | N/A              | N/A                         | N/A                       |
|      | f. Door Size  | N/A              | N/A                         | N/A                       |
| 3.   | Compartmentation  |                  |                             |                           |
|      | • Fire check door   | N/A              | N/A                         | N/A                       |
|      | • Sealing of electrical shafts                              | N/A              | N/A                         | N/A                       |
|      | • Fire Rating of shaft door                                 | N/A              | N/A                         | N/A                       |
|      | • Water Curtain   | N/A              | N/A                         | N/A                       |
|      | • Fire Dampers  | N/A              | N/A                         | N/A                       |
| 4.   | Smoke managements System                                    |                  |                             |                           |
|      | • Basements   | 30 a/c per hour  | N/A                         | N/A                       |
|      | • Upper floors  | 12 a/c per hour  | Natural ventilation         | MR                        |
| 5.   | Fire Extinguishers  |                  |                             |                           |

Narain Lodge Guest House, 8597-98, Desh Bandu Gupta Road, Pahar Ganj, New Delhi-110055

|     |   |   |  |   |
|-----|---|---|--|---|
|     | <ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> </ul>  | 08  | 08   | MR  |
|     |   | .....   | Water Co2 & A.B.C. type.   | MR  |
|     | <ul style="list-style-type: none"> <li>IS marking</li> </ul>  | ISI marked  | Provided   | MR  |
| 6.  | First – Aid Hose Reels  |   |  |   |
|     | <ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>  | 01<br>30 M<br>5 mm  | 01<br>Provided<br>Provided   | MR<br>MR<br>MR  |
| 7.  | Automatic fire detection and alarming system  |   |  |   |
|     | <ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>   | N/A<br>N/A<br>N/A<br>N/A<br>N/A   | N/A<br>N/A<br>N/A<br>N/A<br>N/A  | N/A<br>N/A<br>N/A<br>N/A<br>N/A   |
| 8.  | MOEFA   | Yes   | Provided   | MR  |
| 9.  | Public Address System/Intercom  | Yes   | Provided   | MR  |
| 10. | Automatic Sprinkler System  |   |  |   |
|     | <ul style="list-style-type: none"> <li>Basements</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>   | N/A<br>N/A<br>N/A   | N/A<br>N/A<br>N/A  | N/A<br>N/A<br>N/A   |
| 11. | Internal Hydrants   |   |  |   |
|     | <ul style="list-style-type: none"> <li>Size of riser/down- comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>   | N/A<br>N/A<br>N/A   | N/A<br>N/A<br>N/A  | N/A<br>N/A<br>N/A   |
| 12. | Yard Hydrants   |   |  |   |
|     | <ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>  | N/A<br>N/A  | N/A<br>N/A   | N/A<br>N/A  |
| 13. | Pumping Arrangements  |   |  |   |
|     | <ul style="list-style-type: none"> <li>Ground Level</li> <li>Discharge of main pump</li> <li>Head of main pump</li> <li>Number of main pumps</li> <li>Jockey pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>auto Staring/Manual stopping</li> <li>Pump House Access</li> <li>Terrace level</li> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power supply</li> <li>Auto starting of pump</li> </ul> | N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>450 LPM<br>30 Mtrs.<br>Electric<br>..... | N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>450 LPM<br>30 Mtrs.<br>Electric<br>Switch provided at reception | N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>N/A<br>MR<br>MR<br>MR<br>MR |
| 14. | Captive water Storage for fire fighting   |   |  |   |
|     | <ul style="list-style-type: none"> <li>Under ground tank capacity</li> <li>Draw of connection</li> <li>Fire service inlet</li> <li>Access to tank</li> <li>Overhead Tank capacity</li> </ul>  | N/A<br>N/A<br>N/A<br>N/A<br>2500 ltrs.  | N/A<br>N/A<br>N/A<br>N/A<br>2500 ltrs.   | N/A<br>N/A<br>N/A<br>N/A<br>MR  |
| 15. | Exit Signage  | Yes   | Provided   | MR  |
| 16. | Provision of Lifts  |   |  |   |
|     | <ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of lift lobby</li> </ul>  | N/A<br>N/A  | N/A<br>N/A   | N/A<br>N/A  |

Narain Lodge Guest House, 8597-98, Desh Bandu Gupta Road, Pahar Ganj, New Delhi-110055

|     |  |     |          |     |
|-----|--|-----|----------|-----|
|     | ➤ Communication in lift Car  | N/A | N/A      | N/A |
|     | ➤ Fireman's Grounding Switch   | N/A | N/A      | N/A |
|     | ➤ Lift Signage   | N/A | N/A      | N/A |
| 17. | Standby power supply   | YES | D.G. Set | MR  |
| 18. | Refuge Area  |     |          |     |
|     | ➤ Total area   | N/A | N/A      | N/A |
|     | ➤ Location   | N/A | N/A      | N/A |
| 19. | Fire control room  |     |          |     |
|     | ➤ Detector system panel  | N/A | N/A      | N/A |
|     | ➤ Flow Switch Panel  | N/A | N/A      | N/A |
|     | ➤ PA System Panel  | N/A | N/A      | N/A |
|     | ➤ Batter backup  | N/A | N/A      | N/A |
|     | ➤ Building Floor Plans   | N/A | N/A      | N/A |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any; | N/A | N/A      | N/A |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Name

Designation

*Defo on leave*

Signature of the Inspecting Officer

Name

Designation

*Shalom via Singh Yadav*  
*Divisional Officer (C.D)*

*Shalom via Singh Yadav*  
*08-03-13*