

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/Cinema/2013/ 69

Dated : 14/03/13

FIRE SAFETY CERTIFICATE

Certified that the Regal Cinema at Connaught Place, New Delhi, owned/occupied by Regal Cinema, comprising of ground plus mezzanine only was granted NOC vide letter No. F6/DFS/MS/Cinema/2011/1746 dated 29-07-2011. The Cinema building was inspected by the officers concerned of this department on dated 25-02-2013 in presence of joint inspection team along with Mr. Roopghai (manager) and found that the Cinema building have deemed complied with the fire prevention and fire safety requirements in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and that the building is fit for occupancy Group D " Assembly Building" with effect from ---14/03/13---for a period of three years.

Issued on ---14/03/13---at New Delhi by



Chief Fire Officer

Delhi Fire Service



Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.6933-36/Addl.C.P./Lic.(Cinema) New Delhi dated 13-02-2013.
2. Manager, Regal Cinema, Connaught Place, New Delhi-110001

Condition for the validity of fire safety certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the used and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

25/12/13

FIRE SAFETY INSPECTION REPORT

I.

Sl. No.	APPLIANCES	AVAILABILITY	CONDITION
a.	Overhead/ Underground tank	Provided	O.K.
b.	No. of Hydrants	01	O.K.
c.	No. of Hose Reels	03	O.K.
d.	Number of Fire buckets of sand & water: 1) Main Hall 2) Balcony 3) Box 4) Projector Room 5) Elect. Sub-Station 6) Rectifier Room 7) AC Plant Room 8) Any others	Provided Provided	O.K. O.K.
e.	Number of portable fire extinguishers 1) Main Hall 2) Balcony 3) Box 4) Projector Room 5) Elect. Sub-Station 6) Rectifier Room 7) AC Plant Room 8) Any others	Provided w. CO2 CO2 & ABC Type	O.K.
f.	Number of fire extinguishers for Projector Room.	02 CO2 Type	O.K.
g.	No. of Lightening conductors	Provided	O.K.
h.	Fire alarm system	Provided	O.K.
i.	Sprinkler system		
j.	Escape and exit routes: PRESENT	REQUIREMENT	ANY SUGGESTION/ SHORTCOMINGS
	G.F. 06	Fulfilled	
	Balcony - 02		

II.	Name of trained staff of cinema hall in handling fire safety equipments	Level of Training
a.	SH Shri Ramesh.	Basic Fire Fighting
b.	SH Ashok.	- // -
c.	SH Dalshan Singh.	- // -


III.	Any other comments. Previous shortcoming found removed.
------	--


Signature

Name and designation of the Inspection Officer Dharamvir Singh Yadav

Telephone Number (Office) 011-23416614 (Mobile) 9818343332
011-23416614.

Defects/Shortcomings noted for compliance


Signature & Name of Licensee/Manager
(Telephone No. 23362245)