

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No.F6/MS/DFS/2013/ 74

Dated : 14/03/13

FIRE SAFETY CERTIFICATE

Certified that **Jagatguru Sri Veerasimhasana Math** located at **Plot No. 18,19,M.B. Road,Sector-6, Saket New Delhi.** comprised of **Basement, Ground + 3 Upper Floors** owned/occupied by **Jagatguru Sri Veerasimhasana Math(JSS Academy of Tech.Education)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verify by the officer concerned of fire service on **08/03/13** in the presence of **Mr. P.Rajanna** and that the premises fit for occupancy class **Spiritual Educational Cum Residential Building** with effect from 14/03/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules,2010 subject to conditions printed below.

Issued 14/03/13 at New Delhi by.


14/3
Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Executive Engineer (B) HQ,MCDof Delhi.
Building Department,Town Hall,Delhi.

(2) The Authorized Signatory,
Jagatguru Sri Veerasimhasana Math ,
JSS Academy of Technical Education,C-20/1,Sec-62,Noida-201301.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

- 11/5 -

INSPECTION REPORT

1. Name & address of the building:- Jagatguru Sri Veerasimhasana Math, Plot No. 18, 19, M.B. Road, Sector-6, New Delhi.
2. Type of occupancy:- Spiritual Educational cum Residential Building
3. Type of case:- New
4. Details of previous NOC:- No
5. Fire safety directives No.- F6/DFS/MS/BP/2007/2869 dated 04/10/2007.
6. Date of inspection:- 08/03/2013
7. Name of the inspecting officer:- Dy.C.F.O. Atul Garg & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. P. Rajanna
9. Year of construction :- 2012
10. Applicant's letter No:- JSS/FO/01 dated 17/12/12 Comprised of Basement, Ground + 3 Upper Floors

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/NBC/As per sanctioned plan by MCD vide order No:1743/13/HQ/2007 dated 03/11/2007 Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	Required 12 mtr.	Provided 12 mtr.	MR
	2) Gate width	Required	5 mtr.	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 No.	Provided 2 Nos.	MR
	2. Basements	2 No.	Provided 2 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50Cms, 1.20Cms,	Provided 1.50 mtr. , 1.20 mtr.	MR
	2. Basements	1.50Cms, 1.20Cms,	Provided 1.50 mtr. , 1.20 mtr.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	One	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A

Atul Garg

	2) Sealing of electrical shafts	Yes	Provided	MR
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	25 Nos.	MR
	2) Types		W.Co2& Co2.	MR
	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Required	2 at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Required	Smoke	MR
	2) Location of main panel	Required	Basement	MR
	3) Location of repeater panel	Required	Basement	MR
	4) Alternate source of power	Required	D.G. Set	MR
	5) Hooter's Location	Required	Every floor	MR
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	Yes	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	150 mm.	MR
	2) Number of hydrants per floor	Required	2 Nos.	MR
	3) Hose box	Required	2 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	Required	5 Nos.	MR
	2) Hose box	Required	5 Nos.	MR

13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	1 Nos.	1 Nos.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	2280 LPM	2280 LPM	MR
	g) Stand by pump head	70 mtr.	70 mtr.	MR
	h) Auto starting/Manual stopping	Yes	Provided	MR
	2) Terrace level			
	a) Discharge of pump	900LPM	900LPM	MR
	b) Head of pump	40 Mtr.	40 Mtr.	MR
	c) Power supply	Yes	Yes	MR
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			

Atul Singh

- N/A -

	1) Under ground tank capacity	Required	50,000 ltrs.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10000Ltrs.	10,000 ltrs.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Yes	Provided	MR
	d) Fireman's switch	Yes	Provided	MR

	e) Lift signage	Yes	Provided	MR
17.	Stand by Power Supply	Yes	D.G. Set	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Yes	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	Yes	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put up Please

Signature of the inspecting officer

Signature of the inspecting officer

Name:- Atul Garg

Name:- S.S. Kaushik

Designation:- Dy. Chief Fire Officer

Designation:- Assistant Divisional Officer.