

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/D FS/MS/EH/2013/78

Dated: 15/03/2013

FIRE SAFETY CERTIFICATE

Certified that the **Sinciti Restaurant** (name of the building or premises) located at **1st floor, D-9, Gopal Heights, Netaji Subash Palace, Wazirpur, District Centre, Delhi** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on **25/02/2013** in the presence of **Manager** and that the building/premises is fit for occupancy **Class-D, Assembly** with effect from **15/03/2013** for period of **three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.**

Issued on.....15/03/13.....at New Delhi by


Chief Fire Officer
Delhi Fire Service



Copy to:

1. The Additional Commissioner of Police(Lic.), 1st floor, P.S. Defence Colony, New Delhi
-for information

Following fire safety directives must be adhered to:-

- 1) Means of escape shall not be kept locked or bolted from outside and shall be easily open able by occupants in an event of emergency.
- 2) All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
- 3) The fire suppression/protected arrangements provided in the restaurant are to minimize losses, in maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
- 4) Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
- 5) This report may not in any way be treated as regularization of unauthorized construction, if any.
- 6) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on **www.dfs. delhigovt. nic.in**

M13

INSPECTION REPORT

1. Name & address of the building : Sincity Restaurant, 1st Floor, Gopal Heights, N. Block, Wazirpur, Delhi
2. Type of Occupancy : Assembly
3. Type of Case : New Case/ Renewal Area less than 500 sqm
4. Details of previous NOC : Letter No. F.6/DFSI/MS/2010/2021 Dated: 09/07/2010
5. Fire Safety directives letter No : F.6/DFSI
6. Date of inspection : 25/02/2013
7. Name of the Inspecting Officers: Dy C.F.O., D.O(W), ADD M M
8. Name and designation of officers from the building side : Sh. Manoj Sharma
9. Year of Construction : 2009
10. Applicant's letter No. : Nil dated 22/12/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	50.0 mtr ✓	Provided
	• Gate width	NR	Directly Accessible	MR
	• Width of internal road	NR	NA ✓	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	Provided ✓	MR
	• Basements	11	11	11
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.50 mtr ✓ 1.26 mtr ✓	MR
	• Basements	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	common	with building	
	• Pressurization	Required	Provided ✓	MR
	e. No. of continuous staircases to terrace	11	11	11
	g. Width of Corridor	2	11 ✓	11
	h. Door Size	1.5 mtr	Provided ✓	11
		2 mtr X 2	Provided ✓	11

M/M

Common with building
 Common with mall

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required	Provided	M.R.
		//	//	//
		//	//	//
		//	//	//
		//	//	//
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	Required	M.R.
			//	//
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	4 ABC, ISI marked Required	6 Provided	M.R.
			//	//
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	2 30 m Required 5 mm Required	Common with building Provided	M.R.
			//	//
			//	//
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	smoke heat Basement at each floor Required	Provided // Provided Provided	M.R. M.R. M.R.
		at each floor Required	//	//
8	MOEFA	Required	Provided	M.R.
9	Public Address System.	Required	Provided	M.R.
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	Provided	M.R.
		//	//	//
		//	//	//
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	150 mm	Provided	M.R.

	<ul style="list-style-type: none"> Number of hydrants per floor Hose Box 	02	Provided	MR
12	Yard Hydrants.	02	Provided	MR
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NR	NR	MR
13	Pumping Arrangements.	NR	NR	MR
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	Common with building		
		NR	2850 LPM	MR
		NR	70 mtr.	MR
		NR	02	MR
		NR	180 LPM	MR
		NR	70 mtr.	MR
		NR	2850 LPM	MR
		NR	70 mtr.	MR
		NR	Auto	MR
		NR	Provided	MR
		900 LPM	Provided	MR
		70 mtr.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.	Common with building		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NR	2,00,000 Lts.	MR
		NR	Provided	MR
		NR	Provided	MR
		NR	Provided	MR
		10,000	20,000 Lts.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby 	Required	Provided	M.R.
		11	11	11

N/16

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	<p>11</p> <p>11</p> <p>11</p>	<p>11</p> <p>11</p> <p>11</p>	<p>11</p> <p>11</p> <p>11</p>
17	Standby power supply	Required	Provided.	M.R.
18	Refuge Area.			
	➤ Total Area	NR	Provided	NR
	➤ Location	NR	—	—
19	Fire Control Room	Common with building		
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	Required	Provided	M.R.
		11	11	11
		11	11	11
		11	11	11
		11	11	11
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~.....

S.K. Dua

Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Sumil Choudhary

Signature of the Inspecting Officer

Name Sumil Choudhary

Designation DO (WP)