

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


NO. F6/DFS/MS/2013 / school / 84

Dated: 18 / 03 / 2013

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary School Gashi Bakhtawan  
Pur Delhi ..... comprised of Ground and first  
floor ..... owned/occupied  
by M.C.D. Primary School ..... have complied with fire  
prevention and fire safety requirement in accordance with Direction of Education  
Circular dated 01/03/2011 and verified by the officer concerned of fire service  
on 28-2-2013 ..... in the presence of Shri Bhagwan Gupta ..... and  
that the building /premises is fit for occupancy Educational ..... building  
with effect from 18/03/13 ..... for period of Three years ..... in accordance  
with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and  
subject to compliance of the conditions under rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 18/03/13 ..... at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:- 1. The Principal  
M.C.D. Primary School  
Gashi Bakhtawan Pur Delhi 36.  
2. The Adcl. Director (Edu.)  
North M.C.D. Civic Centre  
New Delhi

Note: Condition for validity of fire safety certificate may kindly be seen overleaf & adhered to.

1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per NOC.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building MCD Primary School, Gahri Baktawar Pur, -Delhi-36
2. Type of Occupancy Educational
3. Type of Case ✓ New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No Circular, Director of Edu. - 1/3/2011
6. Date of inspection : 28-2-2013
7. Name of the Inspecting Officers : ADO SHYAM LAL
8. Name and designation of officers from the building side : Shri Bhagwan Gupta
9. Year of Construction 2009, (Gr. + one)
10. Applicant's letter No. : Nil dated 8-2-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edu. 1/3/11</u> Provided at site Requirement	Remarks MR/NMR
1	Access to building		
	• Road width	<u>Accessible</u> <u>6 m</u>	<u>MIR</u>
	• Gate width	<u>-1-</u> <u>3.6 m</u>	<u>MIR</u>
	• Width of internal road	<u>-1-</u> <u>6 m</u>	<u>MIR</u>
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	<u>2</u> <u>2</u>	<u>MIR</u>
	• Upper Floors	<u>2</u> <u>2</u>	<u>MIR</u>
	• Basements	<u>Nil</u> <u>Nil</u>	<u>Nil</u>
	b. Width of staircases		
	• Upper Floors	<u>1.5 m</u> <u>1.62 m &amp; 1.9 m</u>	<u>MIR</u>
	• Basements	<u>Nil</u> <u>Nil</u>	<u>Nil</u>
	c. Protection of exits		
	• Fire check door	<u>NIR</u>	
	• Pressurization	<u>/</u>	
	e. No. of continuous staircases to terrace		
	g. Width of Corridor	<u>R</u> <u>2.2 m</u>	<u>MIR</u>
	h. Door Size	<u>1 m</u> <u>1.1 m</u>	<u>MIR</u>
3	Compartmentation.		
	• Fire check door	<u>NIR</u>	
	• Sealing of electrical shafts	<u>/</u>	
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	<u>NIR</u>
	• Upper floors	12 a/c per hour	<u>/</u>

5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>02 ABC I Co2 ISI marked (2.5kg)</p>	<p>provided provided provided</p>	<p>MIX MIX MIX</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m 5 mm</p>	<p>NIR /</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		<p>NIR /</p>	
8	MOEFA			
9	Public Address System.			
			<p>NIR NIR</p>	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		<p>NIR /</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		<p>NIR /</p>	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		<p>NIR /</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		<p>NIR /</p>	

14	<b>Captive Water Storage for fire fighting.</b>		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	<b>Exit Signage.</b>		
			NIR
16	<b>Provision of Lifts.</b>		
	• Pressurization of Lift Shaft		N/A
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	<b>Standby power supply</b>		
			NIR
18	<b>Refuge Area.</b>		
	➤ Total Area		NIR
	➤ Location		
19	<b>Fire Control Room</b>		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>		
			NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

D.O. (NW)

Signature of the Inspecting Officer

Name

Designation

1/3/2013  
 (SHYAM 2A2)  
 Assit. Divn. Officer