

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.**

No. F.6/DFS/MS/School/2013/ 92

Dated: 19/03/13

**FIRE SAFETY CERTIFICATE**

Certified that the **Paramount Public School** located at Sec-23, Dwarka, New Delhi-110075 comprised of Ground floor plus three upper floors, having total 77 rooms (Including Class Rooms, Offices, Sci. Lab, Comp. Lab, Sports Room, Library & Store etc.) was issued NOC by this department vide letter No.F.6/MS/DFS/07/141 dated 16.01.2007. The School building was re inspected by the officer concerned of this department on 14.03.2013 in the presence of Sh. Mahender Singh (Accountant) and found that the Delhi Sanskar Bharti Shiksha Samiti have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class educational w.e.f. the date of issue of this certificate for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on.....19/03/13..... at New Delhi.

CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The President,  
Delhi Sanskar Bharti Shiksha Samiti,  
PU-108, Pitampura, Delhi-110088.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi – 110 054.

ofc  
mu

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/S

Ground floor plus three upper floors.

INSPECTION REPORT

1. Name & address of the building : Paramount International School, Sec-23, Dwarka, N.D-75.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. F.6/MS/DFS/2007/141 Date 16.01.2007
5. Fire Safety directives letter No : F.6/DFS/MS/BP/2004/2202 dated 24.09.2004
6. Date of inspection : 14.03.2013
7. Name of Inspecting Officer : A.D.O P.S. Dahiya
8. Name and designation of officers From the building side : Sh. Mahender Singh
9. Year of Construction : 2005-06
10. Applicant's letter No. : PARA. INTL/012-013/314 dated 16.01.2003

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	• Road width	Accessible	18 mtr	MR
	• Gate width	05 mtr	05 mtr	MR
	• Width of internal road	-	-	-
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	Five	Five	MR
	• Basements	-	-	NO Basement
	b. Width of staircases			
	• Upper Floor	-	151, 150, 150, 133, 131 cms	MR, Being a old case
	• Basements	-	-	NO Basement
	c. Protection of exits			
	• Fire check door	-	-	-
	• pressurization	-	-	-
	d. No. of continuous staircases to terrace	-	-	-
	e. Width of Corridor	-	Five	-
	f. Door Size	-	205 cms	-
		-	110 cms x 203 cms	-
3.	Compartmentation			
	• Fire check door	-	-	-
	• Sealing of electrical shafts	-	-	-
	• Fire Rating of shaft door	-	Sealed	-
	• Water Curtain	-	-	-
	• Fire Dampers	-	-	-
		-	-	-
4.	Smoke Management System			
	• Basements	30 a/c per hour	-	NO Basement
	• Upper floors		Natural Ventilation	MR

N/C

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	25 Nos	Provided	MR
	• Types	CO <sub>2</sub> , NCO <sub>2</sub> , ABC	- do -	MR
	• IS marking	ISI marked	ISI Marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	Two	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	-	-	-
	• Location of Main Panel	-	-	-
	• Location of Repeater Panel	-	-	-
	• Alternate source of power	-	D.G Set of 25 kVA	-
	• Hooters' Location	-	-	-
8.	MOEFA	MR	-	-
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	-	-	-
	• Sprinkler above false ceiling	-	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	100 M.M	100 M.M	MR
	• Number of hydrants per floor	Three	Three	MR
	• Hose Box	Two	Two	MR
12.	Yard Hydrants			
	• Total number of hydrants	One	One	MR
	• Hose Box	- do -	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	-	-	-
	➤ Head of Main pump	-	-	-
	➤ Number of main pumps	-	-	-
	➤ Jockey Pump out put	-	-	-
	➤ Jockey pump head	-	-	-
	➤ Standby Pump out put	-	-	-
	➤ Standby Pump Head	-	-	-
	➤ Auto Starting/Manual stopping	-	-	-

N/2

Sec-23, Dwarka, New Delhi- 110075.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
		900LPM, 180LPM	900LPM, 180LPM	MR (02 Pump)
		30M Each Required	30M Each Provided	MR
		-	-	MR
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	50000 Ltr	50000 Ltr	MR
		-	Provided	MR
		-	- do -	MR
		-	- do -	MR
		10000 Ltr	10000 Ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	-	-
		-	-	-
		Required	Provided	MR
		-	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

N/8

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to <sup>Renewal</sup> grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~



Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation