

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. FG/DFS/MS/2013/school/111

Dated: 22/03/2013


**FIRE SAFETY CERTIFICATE**

Certified that the M C Primary Girls School, Shahbad Daulatpur Delhi, is comprised of Ground only – 06 No's sheds & 4 No's pucca rooms, owned/occupied by MCD Primary Boys School complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 07/03/2013 in the presence of Sh. Ranbir Maan and that the building / premises is fit for occupancy of Educational building with effect from 22/03/2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 22/03/13 at New Delhi by

  
Chief fire officer  
Delhi Fire Service

Copy to:

- 1 The Principal, M C Primary Boys School, Shahbad Daulatpur Delhi.
- 2 The Addl. Director of Education, North MCD, Civic Centre New Delhi.

INSPECTION REPORT

1. Name & address of the building: MD Primary Boys School, Shahbad Daulatpur,
2. Type of Occupancy: Educational - Delhi -
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. NIL Dated: \_\_\_\_\_
5. Fire Safety directives letter No: Circular, Director of Edun- 1/3/11
6. Date of inspection: 7-3-2013
7. Name of the Inspecting Officers: ADO SHYAM LAL
8. Name and designation of officers from the building side: sh. Ranbir Mann.
9. Year of Construction: 1962 (Ground only) 6 No's sheds & 4 No's Pucca Rooms.
10. Applicant's letter No.: NIL dated 11/2/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	12 m	MIR
	• Gate width	-11-	3.4 m	MIR
	• Width of internal road	-11-	open ground	MIR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		N/A	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1 m	1.2 m	MIR
3	Compartmentation.			
	• Fire check door		N/A	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		

*Circular  
Dir. of Edun  
1/3/2011*

*one floor less than  
45 student.*



5	Fire Extinguishers		
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>02 ABC ISI marked</p> <p>→</p>	<p>Provided</p> <p>Provided</p> <p>Provided</p>
6	First-Aid Hose Reels.		
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m</p> <p>5 mm</p>	<p>NIR</p> <p> </p>
7	Automatic fire detection and alarming system.		
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		<p>NIR</p> <p> </p>
8	MOEFA		
9	Public Address System.		
			<p>NIR</p> <p>NIR</p>
10	Automatic Sprinkler System.		
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		<p>NIR</p> <p> </p>
11	Internal Hydrants		
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		<p>NIR</p> <p> </p>
12	Yard Hydrants.		
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		<p>NIR</p> <p> </p>
13	Pumping Arrangements.		
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		<p>NIR</p> <p> </p>

M

14	Captive Water Storage for fire fighting.		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	Exit Signage.		
16	Provision of Lifts.		
	• Pressurization of Lift Shaft		N/A
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area		N/A
	➤ Location		/
19	Fire Control Room		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	Special Fire Protection Systems for Protection of special Risks, if any:		
			NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

DO/(NW)

Name

(SHYAM LAL)

Designation

Supd  
1.3

Designation

Ass'tt. Divn. officer

8/3/2012