

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F/DFB/MS/2013/school/99

Dated : 21/03/13

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Pratibha Vikas Vidyalaya at D- 1, Nand Nagri, Delhi-93, comprised of ground plus one upper floor owned/occupied by Rajkiya Pratibha Vikas Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 18.03.2013 in the presence of Sh. Promod Kumar, Principal, of the school and that the building is fit for occupancy class 'B' Educational Building' with effect from21/03/13..... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....21/03/13.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

QC
21.3.13

To,
The Principal
Rajkiya Pratibha Vikas Vidyalaya
D- 1, Nand Nagri, Delhi-93

Copy to:-
The Director of Education
Old Secretariat,
Delhi-110054

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

(G+1)

- H/2
1. Name & address of the building : Rajkiya Pratibha vilas vidyalaya D-1
 2. Type of Occupancy : Educational (G.R.P.) Handwritten No. 93
 3. Type of Case : New Case/ Renewal
 4. Details of previous NOC : Letter No. - N/A - Dated: _____
 5. Fire Safety directives letter No : As per Circular
 6. Date of inspection : 05.11.2011
 7. Name of the Inspecting Officers : Do Virender Singh.
 8. Name and designation of officers from the building side : Mrs Vandana Batra (vice principal)
 9. Year of Construction : 2004.
 10. Applicant's letter No. : Letter dated 05.11.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr	13.5 mtrs	M.R
	• Gate width		4.5 mtr	M.12
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Four	Three	N.M.R
	• Upper Floors	Four	Three	N. M.R
	• Basements			
	b. Width of staircases			
	• Upper Floors	1.5 mtr	1.5 mtr.	M.12
	• Basements	1.5 mtr	1.5 mtr.	M.12
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace	one	one	M.12
	g. Width of Corridor	1.5 mtr	1.5 mtr	M.12
	h. Door Size	1000 mm	1000 mm	M.12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F/DFB/MS/2013/school/99

Dated : 21/03/13

FIRE SAFETY CERTIFICATE

Certified that the Rajkiya Pratibha Vikas Vidyalaya at D- 1, Nand Nagri, Delhi-93, comprised of ground plus one upper floor owned/occupied by Rajkiya Pratibha Vikas Vidyalaya have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 18.03.2013 in the presence of Sh. Promod Kumar, Principal, of the school and that the building is fit for occupancy class 'B' Educational Building' with effect from21/03/13..... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....21/03/13.....at New Delhi by



Chief Fire Officer
Delhi Fire Service

To,
The Principal
Rajkiya Pratibha Vikas Vidyalaya
D- 1, Nand Nagri, Delhi-93

Copy to:-

The Director of Education
Old Secretariat,
Delhi-110054

QC
Beal
21.3.13

CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. **Name & address of the building:** Rajkiya Pratibha Vikas Vidyalaya,
D-1, Nand Nagri, Delhi -93.
2. **Building is comprised of:** Ground +1
3. **Type of Occupancy:** Educational
4. **Type of Case:** New Case
5. **Details of Previous NOC letter:** Nil
6. **Fire Safety Circular No. :** As Per Circular Director of Education dated 01.03.11.
7. **Date of Inspection:** 18.03.2013
8. **Name of the Inspecting officers:** DO Virendra Singh
9. **Name and designation of Officer:** Sh.Parmod Kumar (Principal).
from the building side
10. **Year of Construction:** 2004.
11. **Applicant's letter No:** letter no. Nil dated 04.03.2013

Sr. No.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	6 Mtrs.	13.5 Mtrs.	MR
	• Gate width	-----	4.5 Mtrs.	MR
	• Width of internal road	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	A. Number of Staircases			
	• Upper Floor	04 Nos.	04 Nos.	MR
	• Basement	-----	-----	-----
	B. Width of Staircases			
	• Upper Floor	1.5 Mtrs.	3 Nos. of 1.5 Mtrs. & 1 no. of 75 cm	MR
	• Basement	-----	-----	-----
	C. Protection of exits			
	• Fire check door	-----	-----	-----
	• Pressurization	-----	-----	-----
	D. No. of continuous staircases to terrace	1No.	1No.	MR
	E. Width of Corridor	1.5 Mtrs	1.5 Mtrs	MR
	F. Door Size	1.0 m	1.0 m	MR
3	Compartmentation			
	• Fire check door	-----	-----	-----
	• Sealing of electrical shafts	-----	-----	-----
	• Fire rating of shaft door	-----	-----	-----
	• Water curtain	-----	-----	-----

	• Fire Dampers	-----	-----	-----
4	Smoke Management System			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5	Fire Extinguishers			
	• Total numbers	9 Nos.	26 Nos.	MR
	• Types	ABC & Co ₂	ABC & Co ₂	MR
	• ISI marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	• Total numbers of each floor	-----	-----	-----
	• Length of hose reel hose	-----	-----	-----
	• Nozzle diameter	-----	-----	-----
7	Automatic fire detection and alarming system.			
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	• Hooter's location	-----	-----	-----
8	MOEFA			
9	Public address System.			
10	Automatic Sprinkler System.			
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
	• Sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants			
	• Size of riser/down-comer	-----	-----	-----
	• Number of hydrants per floor	-----	-----	-----
	• Hose Box	-----	-----	-----
12	Yard Hydrants			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements			
	• Ground Level	-----	-----	-----
	• Discharge of main Pump	-----	-----	-----
	• Head of Main Pump	-----	-----	-----
	• Number of main pumps	-----	-----	-----
	• Jockey pump out put	-----	-----	-----
	• Jockey pump head	-----	-----	-----
	• Standby pump out put	-----	-----	-----
	• Standby pump Head	-----	-----	-----
	• Auto Starting /Manual stopping	-----	-----	-----
	• Pump House Access	-----	-----	-----

	<ul style="list-style-type: none"> • Terrace Level 	-----	-----	-----
	<ul style="list-style-type: none"> • Discharge of pump • Head of the Pump • Power supply • Auto Starting of pump 	-----	-----	-----
14	Captive Water Storage for Fire Fighting			
	<ul style="list-style-type: none"> • Underground tank capacity • Draw-off connection • Fire service inlet • Access to tank • Overhead Tank capacity 	-----	-----	-----
15	Exit Signage			
16	Provision of Lifts			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication in lift car • Firemen's grounding switch • Lift Signage 	-----	-----	-----
17	Standby power supply			
18	Refuge Area			
	<ul style="list-style-type: none"> • Total area • Location 	-----	-----	-----
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector system panel • Flow switch panel • PA system panel • Battery backup • Building Floor Plans 	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any			

The fire extinguishers provided in the building were tested/ checked and found functional at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

CFO *Am*

Signature of the Inspecting Officer: *Virendra Singh*
 Name: **VIRENDRA SINGH**
 Designation: **DO (E)**