

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No F 6 / DFS / MS / 2013 / Hospital / 117

DATED 25/03/13

FIRE SAFETY CERTIFICATE

Certified that Hospital building in the name & style of L R S Institute of T B & Respiratory Diseases at Sri Aurbindo Marg, New Delhi comprised of Ground + 03 upper floors was granted NOC by this department vide letter No F 6 / DFS / MS / Hospital / 2008 / 1746 dated 26.06.2008. The premises was re-inspected by the officer concerned of this department on 13.03.2013 in the presence of Mr Jitender Kumar (Fire Officer) and found that the said hospital building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class "Institutional" (Hospital) with effect from 25/03/13..... for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/03/13... at New Delhi



Chief Fire Officer
Delhi Fire Service



Copy to:-

1. The Ex Engineer (Bldg), HQ, Bldg Deptt, MCD, Civic Centre, Minto Road, New Delhi - 02
2. Director, LRS Institute of TB Respiratory disease, Mehrauli, New Delhi - 30

Conditions for validity of Fire Safety Certificate.

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system / equipments non functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction if any,
6. The owner / occupier shall submit a declaration every year in Form K provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

	f. Door Size	02 mtr.	02 mtr.	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers		118	MR
	• Types		WT, CO ₂ , ABC, DCP	MR
	• IS marking		YES	MR
		ISI marked		
6.	First – Aid Hose Reels			
	• Total numbers on each floor	2	2	MR
	• Length of hose reel hose	30 m	YES	MR
	• Nozzle diameter	5 mm	YES	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	Smoke	YES	MR
	• Location of Main Panel	Ground Floor Fire Control Room	YES	MR
	• Location of Repeater Panel	Each floor	YES	MR
	• Alternate source of power	YES	YES	MR
	• Hooters' Location	Each Floor	YES	MR
8.	MOEFA	YES	YES	MR
9.	Public Address System	YES	YES	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 m	YES	MR
	• Number of hydrants per floor	2	2	MR
	• Hose Box	2	2	MR
12.	Yard Hydrants			

Atul Singh
A-TULG ARG

Old Case
Govt. Hospital

	➤ Building Floor Plans	YES	YES	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer


Name

Designation

Signature of the Inspecting Officer

Name

Designation



ATUL GARGY

DLFO