

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/2013/148

Dated: 05/04/2013

FIRE SAFETY CERTIFICATE

Certified that the 22-A, Shivaji Marg, Nazafgarh Road, Near Moti Nagar, New Delhi comprised of ground & two upper floors, was issued NOC vide this office letter No. F6/DFS/MS/2009/1003 dated 15/04/2009. The premises was re-inspected by the officer concerned of this department on **15/02/2013** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the requirement under Rule 33 of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class **office cum Godown (mixed)** with effect from05/04/13.....for a period ofin accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on...05/04/13.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:
Mr. A. Narayanan
22-A, Shivaji Marg, Nazafgarh Road,
Near Moti Nagar, New Delhi

tlc


Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)

1. Name & address of the building : 22-A, Shivaji Marg, Nazafgarh Road, Moti Nagar, New Delhi
2. Type of Occupancy : Office Cum Godown (Mixed)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/1003 dated 15/04/2009
5. Fire Safety directives letter No. : F6/DFS/MS/BP/2003/419 dated 24/02/2003
6. Date of inspection : 15.02.2013
7. Name of the Inspecting Officers : DO (MN)
8. Name and designation of officers
- From the building side : Mr. A. Narayanan
9. Year of Construction : 2005
10. Applicant's letter No. : nil dated 18/12/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

| S. No. | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL Requirement | Provided at site | Remarks MR/NMR |
|--------|---|-----------------|----------------------------|-----------------|
| 1. | Access to building | | | |
| | • Road width | Required | Provided | M.R |
| | • Gate width | Required | 3.5 mtr | M.R, (old case) |
| | • Width of internal road | N.A. | N.A | N.A. |
| 2. | Number, Width, Type & Arrangement of Exits | | | |
| | a. Number of staircases | 02 | 02 | M.R. |
| | • Upper Floors | 02 | 02 | M.R. |
| | • Basement | N.A. | N.A | N.A. |
| | b. Width of staircases | | | |
| | • Upper Floors | 1.25 mtr | 1) 1.20 mtr 2) 1.12 mtr | M.R (old case) |
| | • Basement | N.A. | N.A | N.A. |
| | | | | |


| | | | | |
|----|--|----------------------------|----------|------|
| | c. Protection of exits | | | |
| | • Fire check door | Required | Provided | M.R |
| | • Pressurization | N.R | N.P | N.R. |
| | d. No. of continuous staircases to terrace | 01 | Provided | M.R |
| | e. Width of Corridor | N.R (open) | open | M.R |
| | f. Door size | N.A. | N.A | N.A. |
| 3. | Compartmentation. | | | |
| | • Fire check door | required | Provided | M.R |
| | • Sealing of electrical shafts | N.A. | N.A | N.A. |
| | • Fire Rating of shaft door | N.A. | N.A | N.A. |
| | • Water Curtain | N.A. | N.A | N.A. |
| | • Fire Dampers | N.A. | N.A | N.A. |
| 4. | Smoke Management System. | | | |
| | • Basements | N.A. | N.A | N.A. |
| | • Upper floors | N.A. | N.A | N.A. |
| 5. | Fire Extinguishers | | | |
| | • Total numbers | 11 | Provided | M.R |
| | • Types | ABC & CO ₂ type | Provided | M.R |
| | • IS marking | required | Provided | M.R |
| 6. | First-Aid Hose Rees. | | | |
| | • Total numbers on each floor | 02 | provided | M.R |
| | • Length of hose reel hose | 30 m | provided | M.R |
| | • Nozzle diameter | 5 mm | provided | M.R |

| | | | | |
|------------|--|--------------|----------|------|
| 7. | Automatic fire detection and alarming system. | | | |
| | • Type of detectors | Smoke & Heat | Provided | M.R |
| | • Location of Main Panel | Ground floor | Provided | M.R |
| | • Location of Repeater Panel | N.R | N.A | N.A |
| | • Alternate source of power | N.R | Provided | M.R |
| | • Hooter's Location | N.R | Provided | M.R |
| 8. | MOEFA | Required | Provided | M.R |
| 9. | Public Address System. | N.R | N.A | N.A |
| 10. | Automatic Sprinkler system | | | |
| | • Basement | N/A | N/A | N/A |
| | • Upper Floor | Required | Provided | M.R |
| | • Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | • Size of riser/down-comer | 100 mm | provided | M.R. |
| | • Number of hydrants per floor | 02 | provided | M.R. |
| | • Hose Box | 02 | Provided | M.R. |
| 12. | Yard Hydrants. | | | |
| | • Total number of hydrants | 04 | Provided | M.R |
| | • Hose Box | 04 | Provided | M.R. |
| 13. | Pumping Arrangements. | | | |
| | | | | |

| | | | | |
|---|----------------------------------|-------------|----------|-----|
| | Ground Level | | | |
| | ➤ Discharge of main pump | 1620 LPM | Provided | M.R |
| | ➤ Head of Main pump | 36 mtr | Provided | M.R |
| | ➤ Number of main pumps | 01 | Provided | M.R |
| | ➤ Jockey Pump out put | 180 LPM | Provided | M.R |
| | ➤ Jockey pump head | 36 mtr | Provided | M.R |
| | ➤ Standby pump out put | 1620 LPM | Provided | M.R |
| | ➤ Standby pump Head | 36 mtr | Provided | M.R |
| | ➤ Auto Starting/Manual stopping | auto | Provided | M.R |
| | ➤ Pump Hose Access | | | |
| | | | | |
| | Terrace level | | | |
| | ➤ Discharge of pump | 450 LPM | Provided | M.R |
| | ➤ Head of the pump | 36 mtr | provided | M.R |
| ➤ Power supply | Required | Provided | M.R | |
| ➤ Auto Starting of pump | Required | Provided | M.R | |
| 14. Captive Water Storage for fire fighting. | | | | |
| | Underground tank capacity | 35,000 ltr | Provided | M.R |
| | ➤ Draw -off connection | Required | Provided | M.R |
| | ➤ Fire service inlet | Required | Provided | M.R |
| | ➤ Access to tank | Required | Provided | M.R |
| | ➤ Overhead Tank Capacity | 10,000 ltrs | Provided | M.R |

| | | | | |
|-----|---|----------|----------|------|
| 15 | Exit Signage. | Required | Provided | M.R |
| 16. | Provision of Lifts | | | |
| | • Pressurization of Lift Shaft | N.A. | N.A. | N/A |
| | • Pressurization of Lift lobby | N.A. | N.A. | N/A |
| | • Communication In lift Car | Required | Provided | M.R. |
| | • Fireman's Grounding Switch | Required | Provided | M.R. |
| | • Lift Signage | Required | Provided | M.R. |
| 17. | Standby power supply | Required | Provided | M.R |
| 18. | Refuge Area | N.R. | N.R | N.R |
| | ➤ Total Area | N.R. | N.R. | N.R |
| | ➤ Location | N.R. | N.R. | N.R |
| 19. | Fire Control Room | | | |
| | ➤ Detector System Panel | N.R. | N.R. | N.R |
| | ➤ Flow Switch Panel | N.R. | N.R. | N.R |
| | ➤ PA system Panel | N.R. | N.R. | N.R |
| | ➤ Batter backup | N.R. | N.R. | N.R |
| | ➤ Building Floor plans | N.R. | N.R. | N.R |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | N.R. | N.R. | N.R |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/.



Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O. (M.N.)

Designation