

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No.

156/DFS/MS/2013/181

Dated: 15/04/2013

FIRE SAFETY CERTIFICATE

Certified that the **Shalimar Bagh Club** (name of the building or premises) located at **B – Block, Community Center, Shalimar Bagh** was issued NOC vide this department letter no.F.6/DFS/MS/2010/480 dated 17/2/2010. The premises was re-inspected by the officer concerned of this department on 25/03/2013 in the presence of **Sh. Raman** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The building/ premises is fit for occupancy **Class D, Assembly** with effect from 15/04/2013 for a period of **three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010** subject to conditions printed below.

Issued on 15/04/13 at New Delhi.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel. No. - 011-23414250
Email- cfoz.dlfire@nic.in

Copy to:

1. The Additional Commissioner of Police (Lic.), 1st floor, P.S. Defence Colony, New Delhi.
2. Sh. D.P.Gupta (President), Shalimar Bagh Club, B-Block, Community Center, Shalimar Bagh,

Following fire safety directives must be adhered to

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by occupants in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. Basement shall be used as per NBC.
6. This report may not in any way be treated as regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

M18

RE-INSPECTION

- 1. Name & address of the building : Shalimar Bagh club, Shalimar Bagh.
- 2. Type of Occupancy : Assembly
- 3. Type of Case : Renewal
- 4. Details of previous NOC : -
- 5. Fire Safety directives letter No. : -
- 6. Date of inspection : 25/3/13
- 7. Name of the Inspecting Officers : ADO S.K. Dua
- 8. Name and designation of officers :
From the building side : Mr Raman
- 9. Year of Construction : -
- 10. Applicant's letter No. : -

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width			
	• Gate width			
	• Width of internal road			
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basement			
	b. Width of staircases			

N/19

	<ul style="list-style-type: none"> • Upper Floors • Basement 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 			
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door size			
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floor 			
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marks		
6.	First-Aid Hose Rees.			

M/20

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p>30 m</p> <p>5 mm</p>		
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 			
8. ✓	MOEFA	Required	Provided & functional	MR
9. ✓	Public Address System.	Required	Provided & functional	MR
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p>Required</p> <p>Required</p> <p>NR</p>	<p>Provided</p> <p>Provided in liftout area</p> <p>NA</p>	<p>MR</p> <p>MR</p> <p>NA</p>
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>150 mm</p> <p>01</p> <p>01</p>	<p>Provided</p> <p>Provided. Landing valve is fitted now</p> <p>Provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	—	—	—

	<ul style="list-style-type: none"> • Hose Box 	<p>—</p>	<p>—</p>	<p>—</p>
13. Pumping Arrangements.				
	<p>Ground Level</p> <ul style="list-style-type: none"> ➤ Discharge of main pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby pump out put ➤ Standby pump Head ➤ Auto Starting/Manual stopping ➤ Pump Hose Access <p>Terrace level</p> <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power supply ➤ Auto Starting of pump 	<p>—</p>	<p>—</p>	<p>—</p>
14. Captive Water Storage for fire fighting.				
	<p>Underground tank capacity</p> <ul style="list-style-type: none"> ➤ Draw -off connection ➤ Fire service inlet ➤ Access to tank 	<p>—</p>	<p>—</p>	<p>—</p>

N/22

	➤ Overhead Tank Capacity			
15	Exit Signage. ✓	Required	Additional Signage provided	MR
16.	Provision of Lifts			
	<ul style="list-style-type: none">• Pressurization of Lift Shaft• Pressurization of Lift lobby• Communication In lift Car• Fireman's Grounding Switch• Lift Signage	/		
17.	Standby power supply			
18.	Refuge Area			
	<ul style="list-style-type: none">➤ Total Area➤ Location	/		
19.	Fire Control Room			
	<ul style="list-style-type: none">➤ Detector System Panel➤ Flow Switch Panel➤ PA system Panel➤ Batter backup➤ Building Floor plans	/		
20.	Special Fire Protection Systems for Protection of special Risks, if any:	No		

7.7
BT & K...
150

- 17/23 -

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....



Signature of the Inspection Officer

Signature of the Inspection Officer

Name

S. K. Dua

Name

Designation

ADO (WP)

Designation

