

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/MS/School/2013/155

Dated : 08/04/13

FIRE SAFETY CERTIFICATE

Certified that the E.D.M.C Primary School at Shastri Park,H-Block,Delhi-53,comprised of ground plus one upper floor owned/occupied by E.D.M.C. Primary School at have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011and verified by the officer concerned of this department on 25.02.13 in the presence of Sh.Ashok Kumar Tyagi , Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from ..09/04/13.... for a period of **three** years ,subject to conditions printed overleaf.

Issued on.....08/04/13.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service  
08/04/13

To,  
The Principal  
E.D.M.C Primary School, 1<sup>st</sup> Shift  
Shastri Park,H-Block,Delhi-53,

Copy:-  
1.The Director of Education,EDMC,  
Udypg Sadan,Plot No.419,FIE,  
Patparganj,Delhi -92.  
2. The Principal  
E.D.M.C Primary School, 2<sup>nd</sup> Shift  
Shastri Park,H-Block,Delhi-53,

### CONDITIONS :

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building: EDMC, Primary School at Shastri Park, H-Block, Delhi -53.
2. Building is comprised of : G +1
3. Type of Occupancy : Educational
4. Type of Case : New
5. Details of Previous NOC letter : Nil
6. Fire Safety direction letter No : Circular Director of Education dtd. 01.03.11
7. Date of Inspection : 25.02.13
8. Name of the Inspecting officers : DO Virendra Singh
9. Name and designation of Officer:  
 from the building side : Sh.Ashok Kumar Tyagi (Principal)
10. Year of Construction - : 2011
11. Applicant's letter No : 176/13 dated 25.02.13

NO.	Minimum Standards on fire prevention and fire safety U/R33	Circular Requirement	Provided at Site	Remarks
1	Access to building			
	<ul style="list-style-type: none"> <li>• Road width</li> </ul>	06 M	05 M	Acceptable
	<ul style="list-style-type: none"> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	-----	-----	-----
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	02 Nos.	02 Nos.	MR
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basement</li> </ul>	02 Nos.	02 Nos.	MR
		-----	-----	-----
	B. Width of Staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>	1.5 M	Provided	MR
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	-----	-----	-----
		-----	-----	-----
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Pressurization</li> </ul>	-----	-----	-----
	e. No. of continuous staircases to terrace	-----	1No.	MR
	g. Width of Corridor	1.5 mts.	2.4 mts	MR
	h. Door Size	1.0 Mtrs	1.0 Mtrs	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Sealing of electrical shafts</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire rating of shaft door</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Water curtain</li> </ul>	-----	-----	-----
	<ul style="list-style-type: none"> <li>• Fire Dampers</li> </ul>	-----	-----	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>	-----	-----	-----



	• Upper floor	-----	-----	-----
5.	Fire Extinguishers			
	• Total numbers	6 Nos.	6 Nos.	MR
	• types	ABC & Co2	Provided	MR
	• IS marking	ISI marked	Prrovided	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	-----	-----	-----
	• Length of hose reel hose	-----	-----	-----
	• Nozzle diameter	-----	-----	-----
7	Automatic fire detection and alarming system.			
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	• Hooter's location	-----	-----	-----
8	MOEFA	-----	-----	-----
9	Public address System.	-----	-----	-----
10	Automatic Sprinkler System.	-----	-----	-----
	• Basement	-----	-----	-----
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants			
	• size of riser/down-comer	-----	-----	-----
	• Number of hydrants per floor	-----	-----	-----
	• Hose Box	-----	-----	-----
12	Yard Hydrants.			
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.			
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump	-----	-----	-----

	➤ Head of the Pump	-----	-----	-----
	➤ Power supply	-----	-----	-----
	➤ Auto Starting of pump	-----	-----	-----
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	-----	-----	-----
15	Exit Signage.	-----	-----	-----
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	-----	-----	-----
18	Refuge Area.	-----	-----	-----
	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	-----	-----	-----
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	-----	-----	-----

The fire extinguishers provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name VIRENDRA SINGH

Designation DO (CE)



~~CFO~~ ~~4/4~~  
 4/4  
 Ash