

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**

NEW DELHI- 110001

Email- cfhq.dfire@nic.in,

NO. F6/DFS/MS/EH/2013/ 185

DATED: 18.04.2013

FIRE SAFETY CERTIFICATE

Certified that the M/s Geoffrey's Restaurant (A Unit of Precious Hospitality & Leisure Pvt Ltd), is running at S-21 & 22 Second floor in Select City walk mall, Saket, New Delhi-110017 comprised of three tier basement, ground plus seven upper floors was granted NOC by this department vide letter no. F6/MS/DFS/EH/2009/3859 dated. 21.12.2009. The premises re-inspected by officers concerned of fire service on 28.03.2013 in the presence of Mr. Baldev Singh (Manager), of the restaurant and that the building is fit for occupancy class D "Assembly building (Restaurant)" with effect from 18.4.2013... for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as mentioned below.

Issued on 18.04.2013 at New Delhi by


(Dr.G.C. Misra)
Chief Fire Officer
Delhi Fire Service
Ph.23414333

Copy To:-

1. The Dy. Health Officer, MCD, South Zone, Green Park, New Delhi.
2. The Authorized Signature, M/s Geoffrey's Restaurant (A Unit of Precious Hospitality & Leisure Pvt Ltd), at S-21 & 22 Second floor, Select City walk mall, Saket, New Delhi-110017

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1	Name & address of the building	M/s Geoffrey's Restaurant (A Unit of Precious Hospitality & Leisure Pvt Ltd), is running at S-21 & 22 Second floor, Select City walk mall,		
2	Type of Occupancy	Assembly building "D" Restaurant		
3	Type of case	Renewal		
4	Details of previous NOC	F6/MS/DFS/EH/2009/3859 dated. 21.12.2009		
5	Fire safety directives letter No	Nil		
6	Date of inspection	28.03.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO S.S. Kaushik (BCP/SJ)		
8	Name and designation of officers from the building side	Mr. Baldev Singh (Manager),		
9	Year of construction	Nil		
10	Applicant's letter No.	Nil	15.02.2013	(Resturant running at 2nd floor) Mall bldg is three type basement + Ground + Sewer upper floors -
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	10 Mtr Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	Two	2 Nos. Near Restaurant	MR
	2. basements	N/A	N/A	N/A
	b. Width of staircase			
	1. Upper floors	1.5 Mtr	Provided	MR
	2. basements	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to	Required	Provided by Mall	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	Required	Two Exit Provided	MR
3	Compartmentation.			
	1. Fire check door	Required	Provided by Mall	MR
	2. Sealing of electrical shafts	Required	Provided by Mall	MR
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	N/A	N/A
	upper floors		Mech. Ventilation Provided by Mall	MR
5	Fire Extinguishers			
	total numbers		6 Nos	MR
	Types		ABC, Water Co2	MR
	ISI marking	ISI	Yes	MR

D. Kaushik

✓

6	First-Aid Hose Reels.	Provided & Maintain by Mall		
	total numbers on each floor	do	do	do
	Length of Hose reel hose	do	do	do
	Nozzle Diameter	do	do	do
7	Automatic fire detection and alarming system:-	Provided & Maintain by Mall		
	Type of detectors	do	do	do
	location of Main Panel	do	do	do
	location of Repeater panel	do	do	do
	Alternate source of power	do	do	do
	hooter's location	do	do	do
8	MOEFA	Provided & Maintain by Mall		
9	Public Address System.	Provided & Maintain by Mall		
10	Automatic Sprinkler System.	Provided & Maintain by Mall		
	basement	do	do	do
	upper floors	do	do	do
	sprinkler above false ceiling	do	do	do
11	Internal Hydrants	Provided & Maintain by Mall		
	Size of riser/down-corner	do	do	do
	Number of Hydrants per floor	do	do	do
	hose Box	do	do	do
12	Yard Hydrants.	Provided & Maintain by Mall		
	total number of hydrants	do	do	do
	hose box	do	do	do
13	Pumping arrangements	Provided & Maintain by Mall		
	1. Ground level			
	a. Discharge of main Pump	do	do	do
	b. Head of main pump	do	do	do
	c. Number of main pumps	do	do	do
	d. jockey pump out put	do	do	do
	e. jockey pump head	do	do	do
	f. Standby Pump output	do	do	do
	g. Stanby Pump head	do	do	do
	h. Auto Starting/Manual stopping	do	do	do
	pump house access	do	do	do
	2. Terrace level	do	do	do
	a. Discharge of pump	do	do	do
	b. head of the pump	do	do	do
	c. Power supply	do	do	do
	d. Auto starting of pump	do	do	do
14	Captive water storage for fire fighting	Provided & Maintain by Mall		
	1. Underground tank capacity	do	do	do
	a. Draw-off connection	do	do	do
	b. fire service inlet	do	do	do
	c. Access to tank	do	do	do
	Over head tank Capacity	do	do	do
15	Exit Signage.	do	do	do
16	Provision of lifts.	Provided & Maintain by Mall		
	a. Pressurization of lift shaft	do	do	do
	b. pressurization of lift lobby	do	do	do
	c. communication in lift car	do	do	do
	d. Fireman's grounding switch	do	do	do
	e. Lift signage	do	do	do

6	First-Aid Hose Reels.	Provided & Maintain by Mall		
	total numbers on each floor	do	do	do
	Length of Hose reel hose	do	do	do
	Nozzle Diameter	do	do	do
7	Automatic fire detection and alarming system:-	Provided & Maintain by Mall		
	Type of detectors	do	do	do
	location of Main Panel	do	do	do
	location of Repeater panel	do	do	do
	Alternate source of power	do	do	do
	hooter's location	do	do	do
8	MOEFA	Provided & Maintain by Mall		
9	Public Address System.	Provided & Maintain by Mall		
10	Automatic Sprinkler System.	Provided & Maintain by Mall		
	basement	do	do	do
	upper floors	do	do	do
	sprinkler above false ceiling	do	do	do
11	Internal Hydrants	Provided & Maintain by Mall		
	Size of riser/down-corner	do	do	do
	Number of Hydrants per floor	do	do	do
	hose Box	do	do	do
12	Yard Hydrants.	Provided & Maintain by Mall		
	total number of hydrants	do	do	do
	hose box	do	do	do
13	Pumping arrangements	Provided & Maintain by Mall		
	1. Ground level			
	a. Discharge of main Pump	do	do	do
	b. Head of main pump	do	do	do
	c. Number of main pumps	do	do	do
	d. jockey pump out put	do	do	do
	e. jockey pump head	do	do	do
	f. Standby Pump output	do	do	do
	g. Stanby Pump head	do	do	do
	h. Auto Starting/Manual stopping	do	do	do
	pump house access	do	do	do
	2. Terrace level	do	do	do
	a. Discharge of pump	do	do	do
	b. head of the pump	do	do	do
	c. Power supply	do	do	do
	d. Auto starting of pump	do	do	do
14	Captive water storage for fire fighting	Provided & Maintain by Mall		
	1. Underground tank capacity	do	do	do
	a. Draw-off connection	do	do	do
	b. fire service inlet	do	do	do
	c. Access to tank	do	do	do
	Over head tank Capacity	do	do	do
15	Exit Signage.	do	do	do
16	Provision of lifts.	Provided & Maintain by Mall		
	a. Pressurization of lift shaft	do	do	do
	b. pressurization of lift lobby	do	do	do
	c. communication in lift car	do	do	do
	d. Fireman's grounding switch	do	do	do
	e. Lift signage	do	do	do

17	Standby power supply	Provided & Maintain by Mall		
18	Refuge Area.	Provided & Maintain by Mall		
	total area	do	do	do
	location	do	do	do
19	Fire control room	Provided & Maintain by Mall		
	a. detector system Panel	do	do	do
	b. Flow switch Panel	do	do	do
	c. PA system Panel	do	do	do
	d. Batter backup	do	do	do
	e. Building floor plans	do	do	do
20	Special Fire Protection systems for protection of special risks, if any:			

The fire protection systems provided in the building were checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)



Signature of the inspecting officer

Name S.S. Kaushik

Designation : ADO (BCP/SJ)

