

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2013/134 Dated: 01/04/2013

**FIRE SAFETY CERTIFICATE**

Certified that the **Guru Angad Public School** located at **Gurdwara Complex, Ashok Vihar, Phase-I, Delhi-110052**, is comprised of ground plus three upper floors only, occupied by **Guru Angad Public School**, was issued NOC vide this office letter No. **F6/DFS/MS/2009/205** dated **23/01/2009**. The premises was re-inspected by the officer concerned of this department on **15/02/2012** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the fire prevention and fire safety requirements in accordance with the Delhi Fire Service Act 2007 Rule 2010 and the building /premises is it for occupancy **Class-B (Educational)** with effect from 01/04/13 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule, 2010.

Issued on 01/04/13 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Sh. P.S. Kholi (Manager)  
Guru Angad Public School located at Gurdwara Complex, Ashok Vihar, Phase-I, Delhi-110052
2. The Director of Education, Old Secretariat, Delhi



Note : For general fire safety directives please over leaf.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

173

May kindly peruse letter no. 6649 dated 04.10.12 received from Sh. P.S. Kholi (Manager) for Guru Angad Public School located at Gurdwara Complex, Ashok Vihar, Phase-I, Delhi-110052, regarding issue renewal of NOC from fire and safety point of view. The premises was inspected by the undersigned on dated 15.10.12 & observed that the school building is comprised of ground plus three upper floors only. However following fire safety measures are put up on the prescribe Performa:

1. Name & address of the building : Guru Angad Public School located at Gurdwara Complex, Ashok Vihar, Phase-I, Delhi-110052.
2. Type of Occupancy : Class -B (Educatiuonal)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/2009/205 dated 23/01/2009 ✓
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 15/02/2012
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
8. Name and designation of officers  
From the building side : P.S. Kholi (Manager)
9. Year of Construction : 2003
10. Applicant's letter No. : 6649 dated 04.10.12

**INSPECTION REPORT**

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06 mtrs	12 mtr ✓	Old case M/R
	• Gate width	Old case	Old case ✓	Old case
	• Width of internal road	N.R.	N.R.	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	02 ✓	M/R

M/Y

	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	N.A.
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	Old case	1 staircase 120 cm second is 1 mtr	M/R
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	N.A.
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/R	N/P	N.R.
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/R	N/R	N.R.
	d. No. of continuous staircases to terrace	2	2	M.R.
	e. Width of Corridor	Old case	Old case	Old case M.R.
	f. Door size	Old case	1 mtr appr.	M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/R	N/R	N/R
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/R	N/R	N/R
5.	<b>Fire Extinguishers</b>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	10 nos.	12	M/R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ISI marked ABC & CO <sup>2</sup> type	provided	M/R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	Yes	provided	M/R

M/S

6.	<b>First-Aid Hose Rees.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	Required	provided	M/R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	provided	M/R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	Provided	M/R
7.	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	N/R	N/R	N/R
8.	<b>MOEFA</b>	N/R	N/R	N/R
9.	<b>Public Address System.</b>	Required	Provided	M/R
10.	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	N/R	N/R	N/R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	No false ceiling	N/R	N/R
11.	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	4 "	Provided	M/R
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	One at each floor	Provided	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	required	Provided	M/R
12.	<b>Yard Hydrants.</b>	N/R	N/R	N/R


	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/R	N/R	N/R
		N/R	N/R	N/R
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N/R	N/R	N/R
	➤ Head of Main pump	N/R	N/R	N/R
	➤ Number of main pumps	N/R	N/R	N/R
	➤ Jockey Pump out put	N/R	N/R	N/R
	➤ Jockey pump head	N/R	N/R	N/R
	➤ Standby pump out put	N/R	N/R	N/R
	➤ Standby pump Head	N/R	N/R	N/R
	➤ Auto Starting/Manual stopping	N/R	N/R	N/R
	➤ Pump Hose Access	N/R	N/R	N/R
	<b>Terrace level</b>			
	➤ Discharge of pump	450 & 220 LPM	Provided	M/R
	➤ Head of the pump	40 mtr	Provided	M/R
	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	N/R	N.R.	N.R.
14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>			
	➤ Draw -off connection	N/R	N/R	N/R
	➤ Fire service inlet	N/R	N/R	N/R
	➤ Access to tank	N/R	N/R	N/R

	➤ Overhead Tank Capacity	5,000 ltrs	5,000 ltrs	M.R.
15	Exit Signage.	Required	Provided	M/R
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/R	N/R	N/R
	• Pressurization of Lift lobby	N/R	N/R	N/R
	• Communication In lift Car	N/R	N/R	N/R
	• Fireman's Grounding Switch	N/R	N/R	N/R
	• Lift Signage	N/R	N/R	N/R
17.	<b>Standby power supply</b>			
18.	<b>Refuge Area</b>			
	➤ Total Area	N/R	N/R	N/R
	➤ Location	N/R	N/R	N/R
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N/R	N/R	N/R
	➤ Flow Switch Panel	N/R	N/R	N/R
	➤ PA system Panel	N/R	N/R	N/R
	➤ Batter backup	N/R	N/R	N/R
	➤ Building Floor plans	N/R	N/R	N/R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	N/R

MS

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer



Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O. (M.N.)



Designation