

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001**


No. F6/DFS/MS/School/2013/ 126

Dated: 26/03/13

**FIRE SAFETY CERTIFICATE**

Certified that the **M.C. Primary School (Boys/Girls), Khizrabad (Hindi/Urdu)**, New Delhi (School ID-1958045,46,47,48), comprised of ground plus one upper floor **Owned/ Occupied** by M.C. Primary School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/ Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 28/02/2013 in the presence of Mr. Avinash Kumar, Teacher of the school and that the building/ premises is fit for occupancy class-B "Educational building" with effect from 26/03/13 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 26/03/13 at New Delhi by

  
26/3  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
S/CP

**Copy To: -**







1. The Directorate of Education, Govt. of NCTD, Old Secretariat, New Delhi.
2. The Principal, M.C. Primary School (Boys/Girls), Khizrabad (Hindi/Urdu), ND -25

**Conditions for the validity of fire safety Certificate**

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

## INSPECTION REPORT

1. Name & address of the building : M.C. Primary School (Girls/Boys)  
 : Khizrabad - HINDI/URDU  
 : New Delhi - 110025
2. Type of Occupancy : Educational
3. Type of Case : New
4. Details of previous NOC : Nil Dt. \_\_\_\_\_
5. Fire Safety Directives letter No : Dt of Edn. Circular Dt. 01/3/2011
6. Date of Inspection : 28/2/2013
7. Name of the Inspecting Officer : Dharampal, DO/South
8. Name and designation of the Officers from the building side : Mr. Avinash Kumar, Teacher.
9. Year of Construction : 1988 1. Ground plus one upper floor -  
 2. Ground floor only.
10. Applicant's letter No : Nil

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>6 mts</u>	<u>MR</u>
	• Gate width	<u>NA</u>	<u>4.25 mts</u>	<u>MR</u>
	• Width of internal road	<u>NA</u>	<u>NA</u>	<u>NA</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	• Number of Staircase			
	➤ Upper floors	<u>2</u>	<u>2</u>	<u>MR</u>
	➤ Basement	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of Staircase			
	➤ Upper floors	<u>1.50 mts</u>	<u>1.50 mts each</u>	<u>MR</u>
	➤ Basement	<u>NA</u>	<u>NA</u>	<u>NA</u>
	Protection of Exits		<u>NA</u>	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Width of Corridor	<u>NA</u>	<u>NA</u>	<u>NA</u>
	• Door Size / Width	<u>1.0 mts</u>	<u>1.0 mts</u>	<u>MR</u>

Double door

<b>3</b>	<b>Compartmentation</b>				NA
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>				
<b>4</b>	<b>Smoke Management System</b>				NA
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper Floors</li> </ul>				
<b>5</b>	<b>Fire Extinguishers</b>				
	<ul style="list-style-type: none"> <li>• Total Number</li> <li>• Types</li> <li>• IS marking</li> </ul>	One / 300m <sup>2</sup> ABC / CO2 ISI mark	4 Nos ABE ISI	MR MR MR	
<b>6</b>	<b>First-Aid Hose Reels</b>				NA
	<ul style="list-style-type: none"> <li>• Total Number on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	/Per Floor 30 m 5mm			
<b>7</b>	<b>Automatic Fire Detection and Alarming System</b>				NA
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooter's Location</li> </ul>				
<b>8</b>	<b>MOEFA</b>				Required Provided MR
<b>9</b>	<b>Public Address System</b>				NA
<b>10</b>	<b>Automatic Sprinkler System</b>				NA
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>				
<b>11</b>	<b>Internal Hydrant</b>				NA
	<ul style="list-style-type: none"> <li>• Size of riser/down comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>				
<b>12</b>	<b>Yard Hydrant</b>				NA
	<ul style="list-style-type: none"> <li>• Total Number of hydrants</li> <li>• Hose Box</li> </ul>				



20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional / ~~non-functional~~ at the time of inspection.

Keeping in view the substantial / ~~insubstantial~~ compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at serial Number~~.....

Accordingly, DFA / FT letter is put up for perusal & approval please.

*[Handwritten signature]*

*[Handwritten signature]*  
19/8/13

Signature of Inspecting Officer  
Name: Dharampal Bharadwaj  
Designation: DIV. OFFICER