

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI – 110001

No: F 6/DFS/MS/2013/ 25/03/13

Dated:- 25/03/13

FIRE SAFETY CERTIFICATE

Certified that the MCD Primary Girls School, Khara Kalam
Delhi comprised of Ground floor only
S.N.Os Pucca Rooms & S.N.Os Porja Cabin owned/occupied by MCD
Primary Girls School Khara Kalam. Complied with the fire prevention and fire
 safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
 verified by the officer concerned of Fire Service on 11/3/13 in the presence of
Smt. Shakuntla Mann and that the building/premises is fit for occupancy
Educational building with effect from 25/03/13 for a period of
Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
 Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
 Rules, 2010.

Issued on 25/03/13 at New Delhi.



Chief Fire Officer
 Delhi Fire Service

o/c


Copy to:-

1. The Principal
MCD Primary Girls School
Khara Kalam Delhi 110082

2. The Adell. Director (Edu)
North MCD Civic Centre
New Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per BBL.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.

INSPECTION REPORT

1. Name & address of the building: MCD Primary Girls School, Kharsa Kalan, Delhi-82
2. Type of Occupancy: Educational
3. Type of Case: ~~New Case/ Renewal~~
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No: Circular, Dir. of edum. 1/3/11
6. Date of inspection: 11-3-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAZ
8. Name and designation of officers: Smt. Shakuntala Maan (Principal)
from the building side
9. Year of Construction: 2002, (8 No's Pucca Room & 5 No's Portacabin)
10. Applicant's letter No.: 2007 Nil dated 19-2-2013. (ground only)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of edum. 1/3/2011</u> Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	9 m	M/R
	• Gate width	—	3.85 m	M/R
	• Width of internal road	—	open ground	M/R
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		N/A	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1 m	1.12 m double doors.	M/R
3	Compartmentation.			
	• Fire check door		N/A	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour		
	• Upper floors	12 a/c per hour		

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 ABC ISI marked	provided provided provided	MIR MIR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	NIR /	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		NIR 	
8	MOEFA			
9	Public Address System.			
			NIR NIR	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		NIR /	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		NIR /	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		NIR /	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		NIR 	

14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NIR	
15	Exit Signage.			NIR	
16	Provision of Lifts.				
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			NIA	
17	Standby power supply			NIR	
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			NIA	
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:			—	—
				Nil	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name

Designation

D.O.
(NW)
Gupta

Signature of the Inspecting Officer

Name

Designation

SHYAM LAL

Assist. Divn. Officer