

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001


No. F6/DFS/MS/Hospital/2013/137

Dated: 02/04/13

FIRE SAFETY CERTIFICATE

Certified that the National Society for the Prevention of Blindness- India at Plot No. 8-B, Institutional Area, Karkardooma, Delhi-92, comprised of Basement ground plus three upper floor owned/occupied by National Society for the Prevention of Blindness- India, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on dated 13.03.13 in the presence of Mr. R.S. Negi Representative of the building and that the building is fit for occupancy class C 'Institutional Building' with effect from 02/04/13... for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....02/04/13.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

02  
Red  
07.4.2013

Copy to-

The National Society for the Prevention of Blindness- India  
18, Community Centre, New Friend Colony, New Delhi-25

CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. Basement shall be used as per BBL.

IR 45

**INSPECTION REPORT**

1. Name & address of the building : National Society for the Prevention of Blindness- India, Plot No. 8-B, Institutional Area, Karkardooma, Delhi-92.
2. Building is comprised of : B +G+3
3. Type of Occupancy : Institutional (Non Bedded)
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
7. Date of Inspection : 13.03.13
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer from the building side : Mr. R.S. Negi, Representative
10. Year of Construction : 2013
11. Applicant's letter No : dated 01.03.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	23 m ✓	MR
	Gate width	.....	5 m ✓	MR
	Width of internal road	.....	.....	.....
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 no.	2 no.	MR
	Upper Floor	2 no.	2 no.	MR
	Basement	2 no.	2 no.	MR
	B. Width of Staircases	2 m	2 m, 1 m ✓	MR
	Upper Floor	2 m	2 m, 1 m ✓	MR
	Basement	2 m	2 m, 1 m ✓	MR
	c. Protection of exits	.....	.....	.....
	Fire check door	.....	.....	.....
	Pressurization	.....	.....	.....
	e. No. of continuous staircases to terrace	01 no.	01 no. ✓	MR
g. Width of Corridor	.....	.....	.....	
h. Door Size	1 m	1 m ✓	MR	
3	Compartmentation.			
	Fire check door	Required	Provided	.....
	Sealing of electrical shafts	.....	.....	.....
	Fire rating of shaft door	.....	.....	.....
	Water curtain	.....	.....	.....
	Fire Dampers	.....	.....	.....
	.....	.....	.....	.....
4	Smoke Management System			
	Basement	30a/c per hour	Exhaust	MR ✓
	Upper floor	12 a/c per hour	Ventilated	MR ✓



5.	Fire Extinguisher	Required	Provided	
	Total numbers	10 no.	10 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	01 no.	01 no.	MR
	Length of hose reel hose	30 m	provided	MR
	Nozzle diameter	5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke	Smoke	MR
	Location of main panel	.....	.....	.....
	Location of repeater panel	.....	.....	.....
	Alternate source of power	.....	.....	.....
	Hooters's location	.....	.....	.....
8	MOEFA	Required	Provided	MR
9	Public address System.	.....	.....	.....
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor	.....	.....	.....
	sprinkler above false ceiling	.....	.....	.....
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	01 no.	01 no.	MR
	Hose Box per floor	01 no.	01 no.	MR
12	Yard Hydrants			
	Total number of hydrants	.....	03 no.	.....
	Hose Box	.....	03 no.	.....
13	Pumping Arrangements.		Required	Provided
	• Ground Level	.....	.....	.....
	➤ Discharge of main Pump	.....	.....	.....
	➤ Head of Main Pump	.....	.....	.....
	➤ Number of main pumps	.....	.....	.....
	➤ Jockey pump out put	.....	.....	.....
	➤ Jockey pump head	.....	.....	.....
	➤ Standby pump out put	.....	.....	.....
	➤ Standby pump Head	.....	.....	.....
	➤ Auto Starting /Manual stopping	.....	.....	.....
	➤ Pump House Access	.....	.....	.....
	• Terrace Level	.....	.....	.....
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the Pump	40 m	40 m	MR
	➤ Power supply	.....	.....	.....
	➤ Auto Starting of pump	.....	.....	.....

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	Underground tank capacity	.....	50,000 Liters	✓
	Draw-off connection	.....	.....	.....
	Fire service inlet	.....	.....	.....
	Access to tank	.....	.....	.....
	Overhead Tank capacity	5,000 Liters	10,000 Liters	✓ MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft	.....	.....	.....
	Pressurization of Lift lobby	.....	.....	.....
	Communication in lift car	.....	.....	.....
	Firemen's grounding switch	.....	.....	.....
	Lift Signage	.....	.....	.....
17	Standby power supply	N/A		
18	Refuge Area.	N/A		
	Total area	.....	.....	.....
	Location	.....	.....	.....
19	Fire Control Room	N/A		
	Detector system panel	.....	.....	.....
	Flow switch panel	.....	.....	.....
	PA system panel	.....	.....	.....
	Batter backup	.....	.....	.....
	Building Floor Plans	.....	.....	.....
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Singh*

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*