

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI- 110001


NO. F6/DFS/MS/2013/ 124

DATED: 26/03/2013

FIRE SAFETY CERTIFICATE

Certified that the M/s Natya Tarangini at Plit No. 49-52, Pushp Vihar, Sector-IV, MB Road New Delhi- comprised of basement, ground plus four upper floors (The Management closed & sealed fourth floor "an affidavit submitted") owned/occupied by M/s Natya Tarangini have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service, 2010 and verified by the officers concerned of Fire Service on 12.03.2013 in the presence of Mrs. Kaushalya Reddy (Owner) and that the building is fit for occupancy class B "Educational building" with effect from.....26/03/13... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Subject to condition as mentioned below

Issued on26/03/13..... at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to,

1. The Executive Engineer (Bldg.) HQ, Building Department, SDMC Civic Centre, Minto Road. New Delhi.
2. Mrs. Kaushalya Reddy, M/s Natya Tarangini at Plit No. 49-52, Pushp Vihar, Sector-IV, MB Road New Delhi.

Conditions for the validity of fire safety certificate

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
2. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
3. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The basement shall be used strictly as per the provisions of Building Bye laws.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1	Name & address of the building	M/s Natya Tarangini at Plit No. 49-52, Pushp Vihar, Sector-IV, MB Road New Delhi-		
2	Type of Occupancy	Educational Building "B"		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	F6/DFS/MS/BP/2006/600 dated 10.03.2006		
6	Date of inspection	12.03.2013		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO S.S. kaushik		
8	Name and designation of officers from the building side	Mrs. Kaushalya Reddy (Owner)		
9	Year of construction	(basement, ground plus four upper floors) Fourth floor sealed affidavit submitted.		
10	Applicant's letter No.			
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR / NMR
1	Access to building			
	1) Road width	Required	12 Mtr Provided	MR
	2) Gate width	Required	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	Number, width Type & arrangement of exits			
	a. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos. Provided	MR
	2. basements	2 Nos.	2 Nos. Provided	MR
	b. Width of staircase			
	1. Upper floors	Required	1.50 & 1.25 Mtr provided	MR
	2. basements	Required	1.50 & 3 Mtr provided	MR
	c. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	Required	One Provided	MR
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	1 Mtr	Provided	MR
3	Compartmentation.			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	Required	Provided	MR
	3. Fire Rating of shaft door	Required	Provided	MR
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	Smoke Management system.			
	basement	30 a/c per hour 12 a/c per hour	Ehust Fans Provided	MR
	upper floors		Natural Vent.	MR
5	Fire Extinguishers			
	total numbers		10 Nos	MR
	Types		ABC, Water Co2,	MR
	ISI marking	ISI	Yes	MR

6	First-Aid Hose Reels.			
	total numbers on each floor	Required	Provided	MR
	Length of Hose reel hose	30 Mtr	Provided	MR
	Nozzle Diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system			
	Type of detectors	Required	Smoke Provided	MR
	location of Main Panel	Required	Ground Floor	MR
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	Required	Provided	MR
	hooter's location	Required	Stairs	Provided
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	Size of riser/down-corner	100 MM	Provided	MR
	Number of Hydrants per floor	Required	One Provided	MR
	hose Box	Required	One Provided	MR
12	Yard Hydrants.			
	total number of hydrants	Required	One Provided	MR
	hose box	Required	One Provided	MR
13	Pumping arrangements			
	1. Ground level			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	2. Terrace level			
	a. Discharge of pump	900 LPM	900 LPM Provided	MR
	b. head of the pump	40 Mtr	40 Mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
14	Captive water storage for fire fighting			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	25,000 Ltr Provided	25,000 ltr Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of lifts.			
	a. Pressurization of lift shaft	Required	Provided	MR
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	Required	Provided	MR
	d. Fireman's grounding switch	Required	Provided	MR
	e. Lift signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR

18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	Required	Provided	MR
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	Required	Provided	MR
	d. Batter backup	Required	Provided	MR
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			

The fourth floor of the building closed & sealed, for which the owner have also submitted an affidavit, which is placed opp. in file at page 12 & 13.

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010

Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)



19/8/13

Signature of the inspecting officer

Name S.S. Kaushik

Designation : ADO (South)

