

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2013/149 Dated: 05/04/2013

FIRE SAFETY CERTIFICATE

Certified that the **NEO Convent Sr. Sec. School (Minority)** located at **G -17 area, Paschim Vihar, New Delhi** comprised of **Ground + Two upper floors** occupied by **NEO Convent Sr. Sec. School (Minority)** was issued NOC vide this office letter no. F.6/DFS/MS/2008/2294 dated 11/08/2008. The premises was re-inspected by the officer concerned of this department on 08/02/2013 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 17/01/2005 and the building/ premises is fit for occupancy Class **Educational** with effect from 05/04/2013 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued on 05/04/13 at New Delhi.



**CHIEF FIRE OFFICER
DELHI FIRE SERVICE**



Copy to:

1. The Manager, NEO Convent Sr. Sec. School, G -17 area, Paschim Vihar, New Delhi
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

INSPECTION REPORT

1. Name & address of the building : Neo Convent Sr. Sec. School, Paschim Vihar
2. Type of Occupancy : Educational (Ground + two upper floors)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.6/MS/DFS/2008/2294 Dated: 11/8/08
5. Fire Safety directives letter No : —
6. Date of inspection : 08/3/13
7. Name of the Inspecting Officers : ADO S. K. Dua
8. Name and designation of officers from the building side : Mr. Vedpal (P.T.E)
9. Year of Construction : 2008
10. Applicant's letter No. : NCS/Fire System/01/2012-13 dt. 28/12/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided ✓	MR
	• Gate width	Old Case	—	Old Case
	• Width of internal road	NR	N/A	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	02	03	MR
	• Upper Floors	02	03	MR
	• Basements	N/A	NA	—
	b. Width of staircases		(Provided)	
	• Upper Floors	1.5 mtr.	1.55, 1.80, 1.80 mtr.	MR ✓
	• Basements	NA	NA	—
	c. Protection of exits	—	—	—
	• Fire check door	NA	NA	—
	• Pressurization	NA	NA	—
	e. No. of continuous staircases to terrace	01	03	MR
	g. Width of Corridor	1.5 mtr.	2.25 mtr.	MR ✓
	h. Door Size	Old Case	0.96 mtr	Old Case

- N/6 -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply	Required	62 kVA	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	No	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~


Signature of the Inspecting Officer

Name S.K. Dua

Designation ADO (WP)

Signature of the Inspecting Officer

Name

Designation

E.T letter is ad