

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/DC/2013/119

Dated: 26/03/2013

FIRE SAFETY CERTIFICATE

Certified that the **Shalimar Place** (name of the building or premises) at Plot no. 1, District Centre, Shalimar Bagh (address) comprised of one basement(s) and ground + two upper floors, owned/occupied by VMR Promoters Pvt. Ltd., (name of the company/name of the owner/occupier have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 18.03.2013 (date of inspection) in the presence of Sh. M.K. Madan (Director) (name and address of the owner or his representative) and that the building/premises is fit for **Mercantile** occupancy with effect from 26/03/2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/03/2013 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:
Sh. M.K. Madan (Director)
VMR Promoters Pvt. Ltd.
MFG House, 17-B, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 01.02.13 received from Sh M.K. Madan (Director) regarding of NOC in r/o Plot no.-1 Distt Shalimar Bagh (Shalimar Palace), New Delhi. Accordingly premises was inspected & observed that the building comprised of basement & two upper floors. Fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : Plot no.-1 Distt Shalimar Bagh (Shalimar Palace), New Delhi
2. Type of Occupancy : Mercantile
3. Type of Case : New
4. Details of previous NOC : Nil
5. Fire Safety directives letter No. : F6/DFS/MS/2007/1288 dated 08/05/2007
6. Date of inspection : 18.03.2013
7. Name of the Inspecting Officers : Dy C.F.O (NW), D.O (NW), A.D.O (NW)
8. Name and designation of officers
From the building side : Mr. M. K. Madan (Director)
9. Year of Construction : 2007-2008
10. Applicant's letter No. : nil dated 01.02.13

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtrs	60 mtrs	M.R
	• Gate width	4.5 mtr	Provided	M.R
	• Width of internal road	6 mtr	9 mtr	M.R
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	5	Provided	M.R
	• Basement	5	Provided	M.R

	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors 	1.5 mtr each	Provided	M.R
	<ul style="list-style-type: none"> • Basement 	1.5 mtr each	Provided	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	M.R
	<ul style="list-style-type: none"> • Pressurization 	Required	Provided	M.R
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1.5 mtr	Provided	M.R.
f. Door size	1.5 mtr	Provided	M.R.	
3.	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> • Sealing of electrical shafts 	Required	Provided	M.R.
	<ul style="list-style-type: none"> • Fire Rating of shaft door 	Required	Provided	M.R.
	<ul style="list-style-type: none"> • Water Curtain 	Required	Provided	M.R.
	<ul style="list-style-type: none"> • Fire Dampers 	Required	Provided	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements 	Required	Provided	M.R.
	<ul style="list-style-type: none"> • Upper floors 	Required	Provided	M.R.
5.	Fire Extinguishers			
	• Total numbers	40	45	M.R
	• Types	CO ₂ & ABC type	Provided	M.R
	• IS marking	ISI marks Required	Provided	M.R

6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	3	Provided	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m Required	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm Required	Provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Location of Main Panel 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Location of Repeater Panel 	Each floor	Provided	M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R
	<ul style="list-style-type: none"> Hooter's Location 	at strategic places	Provided	M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System.	Required	Provided	M.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 m.m.	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	3	Provided	M.R
	<ul style="list-style-type: none"> Hose Box 	3	Provided	M.R

12	Yard Hydrants.			
	• Total number of hydrants	4	6	M.R.
	• Hose Box	6	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R	N.R.
	➤ Head of Main pump	N.R.	N.R	N.R.
	➤ Number of main pumps	N.R.	N.R	N.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	40 mtr	Provided	M.R.
	➤ Standby pump out put	N.R.	N.R	N.R.
	➤ Standby pump Head	N.R.	N.R	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R	N.R.
	➤ Pump Hose Access	N.R.	N.R	N.R.
	Terrace level			
	➤ Discharge of pump	900 LPM.	Provided	M.R
	➤ Head of the pump	40 mtrs.	Provided	M.R
	➤ Power supply	Required	Provided	M.R
	➤ Auto Starting of pump	Required	Provided	M.R
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	N.A.	N.A.	N.A.

	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	25,000 ltrs	Provided	M.R
15	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	MR
	• Pressurization of Lift lobby	Required	Provided	MR
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA system Panel	Required	Provided	MR


	➤ Batter backup	Required	Provided	MR
	➤ Building Floor plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	1. Co2 flooding 2. Lighting conducts <i>dn</i> <i>conductor</i>	Provided	M.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


Signature of the Inspection Officer

Name ~~Sanil Chowdhary~~ S.k. Dug

Designation ADO (WP)


Signature of the Inspection Officer

Name ~~Sanil Chowdhary~~ Sanil Chowdhary

Designation DA/US