

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/EH/2013/ 123

Dated: 26/03/2013

FIRE SAFETY CERTIFICATE

Certified that M/s 'WAREHOUSE' restaurant (A unit of Sukhija Bar & Grill Private Limited), located at 1st floor & Mezzanine floor of D-19 & D-20, Inner circle, Connaught Circus, New Delhi-110001 comprised of ground (shops), first & Mezzanine floor (Warehouse restaurant), & second floor (vacant) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service rules, 2010 and verified by the officers concerned of Delhi fire service on 08.03.2013 in presence of Shri Yudhik Malhotra, Manager of the restaurant and that the building/premises is fit for occupancy class D (Assembly Building Sub Division D-3) with effect from 26/03/2013 for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 26/03/2013 at New Delhi by.


26/3
**Chief Fire Officer
Delhi Fire Service**

Copy to: -

1. The Manager, M/s 'WAREHOUSE' restaurant (A unit of Sukhija Bar & Grill Private Limited), D-19 & D-20, Inner circle, Connaught Circus, New Delhi-110001.
2. The Medical Officer of Health, Health Department, NDMC, Palika Kendra, New Delhi
3. The Assistant Commissioner, Restaurant Branch, L & N Block, I.P.Estate, Vikas Bhawan, New Delhi

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
3. Any loss to life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.

INSPECTION REPORT

1. Name & address of the building : M/s 'WAREHOUSE' restaurant (A unit of Sukhija Bar & Grill Private Limited), 1st floor & Mezzanine floor of D-19 & D-20, Inner circle, Connaught Circus, New Delhi-110001
2. Type of Occupancy : Eating House
3. Type of Case : New case
4. Details of previous NOC : N/A
5. Fire Safety directives letter No : N/A
6. Date of inspection : 08.03.2013
7. Name of the Inspecting Officers : Dharamvir Singh Yadav, DO(CD) and M.K.Chattopadhyay, ADO(CC)
8. Name and designation of officers
from the building side : Mr. Yudhik Malhotra, Manager
9. Year of Construction : Prior 1962
10. Applicant's letter No. : Nil dated 28-12-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<i>001</i> NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mts	More than 06 mts	MR
	• Gate width	-----	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	----	-----	-----
	• Upper Floors	02	03	MR
	• Basements	N/A	N/A	N/A
	b. Width of staircases	-----	-----	-----
	• Upper Floors	1.25 mts	1.30 mts, 1.22 mts & 1.0 mts (G to 1 st floor), 1.48 mts (1 st to Mez. Floor)	MR being old bldg prior to 1983
	• Basements	N/A	N/A	N/A
	c. Protection of exits	-----	-----	-----

	<ul style="list-style-type: none"> • Fire check door • Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	1.5 mts	provided	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A Provided	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	08 ABC, W.CO ₂ ISI marked	Provided Provided Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01 30 m 5 mm	Provided Provided Provided	MR MR MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A


	<ul style="list-style-type: none"> Hooters' Location 	N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	MR
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	MR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	Provided	MR
	<ul style="list-style-type: none"> Number of hydrants per floor 	01	Provided	MR
	<ul style="list-style-type: none"> Hose Box 	01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Hose Box 	N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> ➤ Pump House Access 	N/A	N/A	N/A

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		900 LPM, 180 LPM	provided	MR
		40 mts	Provided	MR
		Required	provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10,000 lts	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17	Standby power supply	Required	Provided (200 KVA)	MR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel 	N/A	N/A	N/A
		N/A	N/A	N/A


	<ul style="list-style-type: none"> • PA System Panel 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Batter backup 	N/A	N/A	-----
	<ul style="list-style-type: none"> • Building Floor Plans 	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher found Provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


M.K. Chattopadhyay
Asstt. Div. Officer (CC)

ref on leave


Dharamvir Singh Yadav
DO(CD)