

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/182

Dated: 16/04/2013

FIRE SAFETY CERTIFICATE

Certified that the Yuva Shakti Model School is comprised of Basement +Ground + Three upper Floor owned/occupied by Yuva Shakti Model School located at Secter-3, Rohini, Delhi-110085 has already been issued Fire Safety Certificate Vide letter no F-6/DFS/MS/09/2124/Dated 16/07/09. The premises was re inspected by the officer concerned of this department on 14/03/2013 in the presence of Sh. Harinder Kumar (Principal) and have deem complied with fire prevention & fire safety requirement in accordance with the circular no. 262-362 at 17/01/05 issued by Director of Education. The premise is fit for occupancy of Group Class B (Educational) with effect from 16/04/2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 16/04/2013 at New Delhi by


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 23414250
Cfosz.dlfire@nic.in

Copy to:

1. The Principal, Yuva Shakti Model School, Sec-3 Rohini, Delhi 110085.
2. The Director of Education, Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : Yuva Shakti Model School, Sec-3, Rohini, Delhi 85.
2. Type of Occupancy : Education
3. Type of Case : Renewal
4. Details of previous NOC : Letter No. F6/DFS/MS/09/2/24 Dated: 16/07/2009
5. Fire Safety directives letter No : Dir of Edu.
6. Date of inspection : 14/03/13
7. Name of the Inspecting Officers : DO NW (S.S Tuli)
8. Name and designation of officers
from the building side : Sh Harinder Kumar (Principal)
9. Year of Construction : 1991
10. Applicant's letter No. : YMS/ 172/V-F/36/Rudrak/2009/8026 DATED 22/02/13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building	Old case		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 		N/A	/
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 			
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 		N/A	/
	d. No. of continuous staircases to terrace			
	e. Width of Corridor			
	f. Door Size			
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	/
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		N/A

5	Fire Extinguishers	30	30	M.R
	<ul style="list-style-type: none"> Total numbers Types IS marking 	ISI marked	ABC, CO ₂ , DCP	M.R
			Yes	M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	04 30 m 5 mm	04 P P	M.R M.R M.R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		N/A	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	R	P	mR
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	4" 04 04	P P P	M.R M.R M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		N/A	
		R	P	M.R
			N/A	

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
15	Exit Signage.	R	P	M.R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply			
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....*NIL*.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name
Designation

DCFO (W2)

Name
Designation

Deepak
1/4/13
SS Tuli