


No F 6 / DFS / MS / 2013 / 203

Dated 25/04/13

**FIRE SAFETY CERTIFICATE**

Certified that the Barbeque Nation Restaurant located at M-A 04, GF, DLF Place Mall, Saket, New Delhi, was inspected by the officer concerned of this department on 12.04.2013 in the presence of Mr. Vishal and found that the said Restaurant have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" with effect from - 25/4/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 25/4/13 at New Delhi by.

  
(Dr. G.C. Misra)  
Chief Fire Officer  
Delhi Fire Service

9/CA

1. M/s Barbeque Nation Hospitality Ltd.,  
Mr. Prosenjit Roy Choudhary,  
M-A04, GF, DLF Place Mall, Saket, New Delhi.
2. The Dy. Health Officer, Health Department,  
South Zone, MCD, New Delhi.

Conditions for the validity of fire safety certificate

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire protection measures shall be maintained in perfect working conditions all the times as seen during inspection.
3. All the staff members must know the correct method operation of fire fighting system.
4. Any lapse rendering fire fighting system/equipment non-functional shall be risk and responsibility of the management.
5. This inspection report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

New Core

**INSPECTION REPORT**

1. Name & address of the building: Barbeque Nation Hospitality Ltd., M-A04, GF,  
DLF Place Mall, Saket, New Delhi.
2. Type of Occupancy : Assembly
3. Type of Case : New Case / ( but it is situated in the mall  
which has already got NOC) *NO-FE/DFS/ms/2011/2383*  
*dated 30/9/11*
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : Nil
6. Date of inspection : 12.04.2013
7. Name of the Inspecting Officer : Dy. CFO Atul Garg
8. Name and designation of Officer  
from the building side : Mr. Vishal
9. Year of Construction : N/A
10. Applicant's letter No. : MCD Letter No DHO/SZ/2012/13-/D/2270 Dated 26.03.2013  
(Restaurant situated at Ground Floor only)

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC /BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	N/A	As it is situated at GF
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
	• Basements	N/A	N/A	situated at GF
	a. Width of staircases	N/A	N/A	situated at GF
	• Upper floors	N/A	N/A	situated at GF
	• Basements	N/A	N/A	situated at GF
	b. Protection of exits			
	• Fire check door			
		YES	YES	MR

	• Pressurization	N/A	N/A	N/A
	c. No of continuous staircase to terrace	N/A	N/A	N/A
	d. Width Of Corridor	N/A	N/A	N/A
	e. Door Size	2.00/1.50 mtr	YES	MR (03 doors provided)
3.	Compartmentation			
	• Fire check door	YES	YES	MR
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	N/A	N/A
5.	Fire Extinguishers			
	• Total numbers	02 each type	YES	MR
	• Types	WT, CO <sub>2</sub> , DCP	YES	MR
	• IS marking	YES	YES	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	YES	MR
	• Length of hose reel hose	30 m	YES	YES
	• Nozzle diameter	5 m m	YES	YES
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	YES	MR
	• Location of Main Panel	YES	YES	MR
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	YES	YES	MR
	• Hooters' Location	YES	At entrance	MR
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	N/A	MR
10.	Automatic Sprinkler System			
	• Basements	N/A	N/A	N/A
	• Upper Floor	N/A	YES	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	YES	MR (already available in the bldg.)
	• Number of hydrants per floor	1	YES	MR
		1	YES	MR

*Handwritten signature*

The Barbeque Mall, M-A, CA, 9, f, DLF Place.

12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Discharge of main pump	CONNECTED TO MAIN FIRE PUMP HOUSE OF MALL		MR
	➤ Head of main pump			MR
	➤ Number of main pumps			MR
	➤ Jockey pump out put			MR
	➤ Jockey pump head			MR
	➤ Standby Pump out put			MR
	➤ Standby Pump Head			MR
	➤ Auto Staring/Manual stopping			MR
	➤ Pump House Access			MR
	• Terrace level			MR
	➤ Discharge of pump			MR
	➤ Head of the pump			MR
	➤ Power supply			MR
	➤ Auto starting of pump			MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	YES	Common water Tank is available	MR
	➤ Draw of connection	YES	YES	MR
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	N/A	N/A	N/A
15.	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A

A. K. Singh

	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

X

Name

ATULGARG

Designation

Designation

DCFO

