

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110 001.

No.F.6/DFS/MS/School/2013/ 220

Dated: 26/04/13

FIRE SAFETY CERTIFICATE

Certified that the building of **Bright Angels Public School** located at C-7, A-Block, Siddharti Enclave, Gali No-2, Bhagwati Garden Extn, Jain Road, New Delhi-110059 comprised of ground floor plus two upper floors. The school is running at ground floor and first floor only, having total 08 rooms (Including Class Rooms & Office etc.), the second floor is being used by the owner for personal purpose owned/occupied by the school management was inspected by the officer concerned of this department on 16.04.2013 in the presence of Sh. H.S. Katiyar (Chairman) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" w.e.f. the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on..... 26/04/13 .....at New Delhi.

CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

Copy to:-

1. The Manager,  
Bright Angels Public School,  
C-7, A-Block, Siddharti Enclave, Gali No-2,  
Bhagwati Garden Extn, Jain Road, N.D-59.
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi - 110054.

9/2  
m

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

N/1.

Ground floor plus two upper floors  
The School is running only at Ground floor & first floor

## INSPECTION REPORT

1. Name & address of the building: Bright Angels Public School, C-7, A-Block, Siddharthi Enclave, N.D-59.  
 2. Type of Occupancy: Educational (School)  
 3. Type of Case: New Case/Renewal  
 4. Details of Previous NOC: Letter No. N/A Dated \_\_\_\_\_  
 5. Fire Safety directives letter No: N/A  
 6. Date of inspection: 16.04.2013  
 7. Name of Inspecting Officer: A.D.O P.S. Dahiya  
 8. Name and designation of officers  
 From the building side: Sh. H.S. Katiyar (Chairman)  
 9. Year of Construction: 2003  
 10. Applicant's letter No.: Nil dated Nil

No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>04.70mts</u>	<u>MR</u>
	• Gate width	<u>-</u>	<u>130cms</u>	<u>MR</u>
	• Width of internal road/side rd	<u>-</u>	<u>09mts</u>	<u>MR</u>
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	<u>One</u>	<u>One</u>	<u>MR</u>
	• Basements	<u>-</u>	<u>-</u>	<u>No Basement</u>
	b. Width of staircases			
	• Upper Floor	<u>155cms</u>	<u>155cms</u>	<u>MR</u>
	• Basements	<u>-</u>	<u>-</u>	<u>No Basement</u>
	c. Protection of exits			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• pressurization	<u>-</u>	<u>-</u>	<u>-</u>
	d. No. of continuous staircases to terrace	<u>-</u>	<u>One</u>	<u>-</u>
	e. Width of Corridor	<u>-</u>	<u>155cms</u>	<u>-</u>
	f. Door Size	<u>-</u>	<u>88cms x 190cms</u>	<u>MR, Being a Old Bldg.</u>
3.	<b>Compartmentation</b>			
	• Fire check door	<u>-</u>	<u>-</u>	<u>-</u>
	• Sealing of electrical shafts	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Rating of shaft door	<u>-</u>	<u>-</u>	<u>-</u>
	• Water Curtain	<u>-</u>	<u>-</u>	<u>-</u>
	• Fire Dampers	<u>-</u>	<u>-</u>	<u>-</u>
4.	<b>Smoke Management System</b>			
	• Basements	<u>30 a/c per hour</u>	<u>-</u>	<u>No Basement</u>
	• Upper floors		<u>Natural Ventilation</u>	<u>MR</u>

N/A

12 a/c per hour

5.	Fire Extinguishers				
	• Total numbers				
	• Types	06 Nos CO <sub>2</sub> , ABC	Provided		MR
	• IS marking	ISI marked	- do		MR
6.	First-Aid Hose Reels		ISI Marked		MR
	• Total numbers on each floor				
	• Length of hose reel hose	30 m			
	• Nozzle diameter	5 mm			
7.	Automatic fire detection and alarming system				
	• Type of detectors				
	• Location of Main Panel				
	• Location of Repeater Panel				
	• Alternate source of power				
	• Hooters' Location		B.G. Set of 5 KVA Near Office		
8.	MOEFA				
9.	Public Address System				
10.	Automatic Sprinkler System				
	• Basement				
	• Upper Floor				NO Basement
	• Sprinkler above false ceiling				
11.	Internal Hydrants				
	• Size of riser/down-comer				
	• Number of hydrants per floor				
	• Hose Box				
12.	Yard Hydrants				
	• Total number of hydrants				
	• Hose Box				
13.	Pumping Arrangements				
	• Ground Level				
	➤ Discharge of main Pump				
	➤ Head of Main pump				
	➤ Number of main pumps				
	➤ Jockey Pump out put				
	➤ Jockey pump head				
	➤ Standby Pump out put				
	➤ Standby Pump Head				
	➤ Auto Starting/Manual stopping				

N/3.

C-7, A Block, Siddharti Enclave,  
Gali No - 2, Bhagwati Garden Extn,  
Jain Road, New Delhi - 110059.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	-	-	-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	-	-	-
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	No Lift
		-	-	-do-
		-	-	-do-
		-	-	-do-
		-	-	-do-
17.	<b>Standby power supply</b>	-	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	-	-	-
		-	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	-	-	-
		-	-	-
		Required	Provided	MR
		-	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	-	-	-

N/4.

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building is comprised of Ground floor plus two upper floors. But the school is running at Ground floor and first floor only. The second floor is used by the owner for personal use. The first floor is served by a single staircase having width 188 cm. There are total 08 Rooms including classrooms, Office etc. In each class students less than 45. The FSC is recommended only for Ground floor & first floor as school running at Ground floor & first floor only as per affidavit submitted by Sh. H. S. Kafiyar.

Signature of Inspecting Officer

Name P. S. Bahiga

Designation Asstt. Divisional Officer.

Signature of Inspecting Officer

Name

Designation