

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F810FS/MS/School/2013/202

Dated: 25/04/2013

FIRE SAFETY CERTIFICATE

Certified that the **D. N Public School, Majra Dabas, Delhi 110081.** is comprised of **Ground floor only (8 no Class Rooms,** owned/occupied by **D.N Public School.** complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and verified by the officer concerned of Fire Service on 28/03/2013 in the presence of **Sh. Biney Kumar** and that the building / premises is fit for occupancy of **Educational** building with effect from **25 / 04 / 2013** for a period of **three years,** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on **25/04/2013** at New Delhi by


25/4
(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfo@dlfire@nic.in

Copy to:

1. The Principal, D. N Public School, Majra Dabas, Delhi 110081.
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi



Renewal

INSPECTION REPORT

1. Name & address of the building: D.N. Public School, Magra Dabas, Delhi-81
2. Type of Occupancy: Educational
3. Type of Case: : New Case/ Renewal
4. Details of previous NOC: : Letter No. F-6/DFs/ms/09/878 Dated: 27-3-2009
5. Fire Safety directives letter No: Circular, Dir. of Edm. 17-1-2005.
6. Date of inspection: : 18-3-2013
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Sh. Biney Kumar
9. Year of Construction: 2006, (Ground only, 8 No's Pucca Rooms) (Classrooms)
10. Applicant's letter No.: : DNPS/02/13 dated 12-2-2013

(old case)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edm. Requirement 17-1-2005	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	12 m	MIR ✓
	• Gate width	-h-	3.74 m	MIR ✓
	• Width of internal road	-h-	N/A	N/A ✓
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		N/A	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1 m	1 m with fitting one door, less than 1/5 student.	MIR (old case) ✓
3	Compartmentation.			
	• Fire check door		N/A	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	MIR 	
	• Upper floors	12 a/c per hour		

5	Fire Extinguishers		
	<ul style="list-style-type: none"> Total numbers Types IS marking 	02 ABC ISI marked	Provided. MIR / Provided MIR / Provided MIR /
6	First-Aid Hose Reels.		
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	30 m 5 mm	NIR /
7	Automatic fire detection and alarming system.		
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 		NIR /
8	MOEFA		
9	Public Address System.		
			NIR NIR
10	Automatic Sprinkler System.		
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 		NIR /
11	Internal Hydrants		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 		NIR /
12	Yard Hydrants.		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		NIR /
13	Pumping Arrangements.		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		NIR /

	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 			NIR
15	Exit Signage.			NIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			NIA
17	Standby power supply			NIR
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 			NIA
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			NIA
20	Special Fire Protection Systems for Protection of special Risks, if any:			NIL

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

[Handwritten signature]

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Do. (rw)

Name

SHYAM LAZ

Designation

[Handwritten signature]

Designation

Asstt. Divn. officer