

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

Fax: 23412593 E-mail: cfohq.dlfire@nic.in

No F610FS/ms/school/2013/201

Dated 25/04/2013

FIRE SAFETY CERTIFICATE



Certified that the Govt. Girls / Boys Sr. Sec. School, No-2 B Block Yamuna Vihar, Delhi, having three Bldg. blocks, whereas two blocks comprises of ground & first floor and one block with ground floor, with 63 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD and verified by the officer concerned of this department on 05-04-2013 in the presence of the Principal, and that the building is fit for occupancy, class B "Educational Building" with effect from 25-4-2013 for a period of three years, subject to conditions printed overleaf.

Issued on 25/04/2013 at New Delhi.


(DR.G.C.MISRA)
Chief Fire Officer
Delhi Fire Service
Ph. 23414333

Copy to:-

1. The Principal
Govt. Girls Sr. Sec. School
No-2 B Block Yamuna Vihar
Delhi 110053
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054
3. The Principal
Govt. Boys Sr. Sec. School
No-2 B Block Yamuna Vihar
Delhi 110053

Conditions

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. Any deviation, with regard to construction, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier of the building shall, under clause 38 of the DFS Rules, declare in Form "K" every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

INSPECTION REPORT

- 111-
1. Name & address of the building: GGSSS No-2 B Block, Yamuna Vihar, Delhi-110053.
 2. Building is comprised of : Ground & First floor
 3. Type of Occupancy : Educational.
 4. Type of Case : New Case
 5. Details of Previous NOC letter: NA
 6. Fire Safety directive letter No : NA
 7. Date of Inspection : 05-04-2013
 8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
 9. Name and designation of Officer: Principal
from the building side
 10. Year of Construction : 1988
 11. Applicant's letter No : GGSSS/B-2/YV/12-13/1245 dated
26-02-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	Director Education	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	25 ft	MR
	• Gate width	Accessible	4Mtrs.	MR
	• Width of internal road	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2Nos. Each Block	2Nos. Each Block	MR
	• Basement	NA	NA	NA
	B. Width of Staircases
	• Upper Floor	02Nos.	1.5Mtr.& 1.46 Mtrs	MR
	• Basement	NA	NA	NA
	c. Protection of exits	-----	-----	-----
	• Fire check door	NA	NA	NA

19/2-

	<ul style="list-style-type: none"> • Pressurization 	-----	-----	-----
	e. No. of continuous staircases to terrace	02	2No.	MR
	g. Width of Corridor	-----	-----	-----
	h. Door Size	1.0Mtr	1.0mtr	MR
3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper floor 	-----	-----	-----
		-----	-----	-----
5	Fire Extinguishers	NA		
	• Total numbers	14 Nos.	19 Nos.	MR
	• Types	ABC&CO2	ABC& CO2	MR
	• IS marking	Req.	Yes.	MR
6	First-aid-Hose Reels.	NA		
	• Total numbers at ground floor	-----	-----	-----
	• Length of hose reel hose	-----	-----	-----
	• Nozzle diameter	-----	-----	-----
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	Hooter's location	-----	-----	-----
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	-----	-----	-----
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	-----	-----	-----
	• Number of hydrants per floor	NA	NA	NA

11/3-

GGSSS No 2, B Block, Yamuna Vihar, Delhi

	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump	-----	-----	-----
	➤ Head of the Pump	-----	-----	-----
	➤ Power supply	-----	-----	-----
	➤ Auto Starting of pump	-----	-----	-----
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	-----	-----	-----
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	-----	-----	-----
	• Location	-----	-----	-----

-7/4-

19	Fire Control Room	NA	NA	NA
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20.	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director Education, GNCTD and in the light of office order No. F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to grant Fire Safety Certificate.

Gurpreet Singh
10/11/13

Signature of the Inspecting Officer

D/E

Name Gurpreet Singh

Designation ADO (N)

Submitted for approval please