

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/School/2013/214

Dated: 26/04/2013

**FIRE SAFETY CERTIFICATE**

Certified that the MCD Primary Boys School, Auchandi Delhi 110039. is comprised of Ground floor only owned/occupied by MCD Primary Boys School. complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 18/03/2013 in the presence of Sh. Vinod Sharma and that the building / premises is fit for occupancy of Educational building with effect from 26/04/2013 for a period of three years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules, 2010.

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 26.04.13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, MCD Primary Boys School, Auchandi, Delhi-110039.
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.



INSPECTION REPORT

1. Name & address of the building : MED Primary Boys School, Ancharoli, Delhi.
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No : Circular, Director, of Edcm. 1/3/2011
6. Date of inspection : 18-3-2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers : Sh. Vinod Sharma  
from the building side : \_\_\_\_\_
9. Year of Construction : 2008, (Ground only)
10. Applicant's letter No. : Nil dated 8/2/2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edcm. 1/3/2011</u> Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>18 m</u>	<u>MIR</u>
	• Gate width	<u>-n-</u>	<u>3.75 m</u>	<u>MIR</u>
	• Width of internal road	<u>-n-</u>	<u>open ground</u>	<u>MIR</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		<u>N/A</u>	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1. m</u>	<u>1.03 m (Double doors)</u>	<u>MIR</u>
3	Compartmentation.			
	• Fire check door		<u>N/A</u>	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	30 a/c per hour	<u>N/A</u>	
	• Upper floors	12 a/c per hour		





14	<b>Captive Water Storage for fire fighting.</b>				
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>			NIR	
15	<b>Exit Signage.</b>			NIR	
16	<b>Provision of Lifts.</b>				
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			NIA	
17	<b>Standby power supply</b>			NIR	
18	<b>Refuge Area.</b>				
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>			NIA	
19	<b>Fire Control Room</b>				
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:			—	NIL —

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

DO. (NW)

Name

(SHYAM LAL)

Designation

Asst. Divn. Officer

Designation

Asst. Divn. Officer