



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6(DFS/MS/School/2013/23)

Dated: 01 / 05 / 2013

**FIRE SAFETY CERTIFICATE**

Certified that the MCD Primary Girls/Boys School, Sect. 7-B, Rohini Delhi 110085 is comprised of Ground + One upper floor & hall (12.5 m x 24.5 m) with three exits width 2.62 m each owned/occupied by MCD Primary Boys/Girls School complied with the fire prevention and fire safety requirements in accordance with the Circular, Director of Education dated 01/03/2011 and verified by the officer concerned of Fire Service on 20/03/2013 in the presence of Smt. Jasbir Kaur and that the building / premises is fit for occupancy of Educational building with effect from 01 / 05 / 2013 for a period of three years, subject to the conditions mentioned over leaf:

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 01/05/13 at New Delhi

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

Copy to: 1. The Principal, MCD Primary Girls/Boys School, Sect. 7-B, Rohini Delhi  
2. The Addl. Director of Education, North MCD, Civic Centre New Delhi.





INSPECTION REPORT

1. Name & address of the building Med Primary B/G. School, Sect. 7, B, Rohini, - Delhi-85.
2. Type of Occupancy Educational
3. Type of Case New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No Circular, Dir. of Edun. 1/3/2011
6. Date of inspection : 20-3-2013
7. Name of the Inspecting Officers : ADO-SHYAM LAL
8. Name and designation of officers from the building side : Smt. Jasbir Kaur.
9. Year of Construction : 2013, (Gr. +1) [one hall with 3 doors width. 2.62m each area (12.5m x 24.5m)]
10. Applicant's letter No. : Nil dated 17-1-2013

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular, Dir. of Edun. Requirement 1/3/2011</u> Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	<u>Accessible 12 m</u>	<u>M/R</u>
	• Gate width	<u>-n-</u> 4.5 m	<u>-n-</u>
	• Width of internal road	<u>-n-</u> open ground	<u>-n-</u>
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	<u>Block-I=2 Block-II=1</u>	<u>Block-I=2 Block-II=1</u> M/R
	• Upper Floors	<u>-do-</u>	<u>-do-</u> M/R
	• Basements	<u>Nil</u>	<u>Nil</u>
	b. Width of staircases		
	• Upper Floors	<u>1.5m.</u>	<u>1.5m each</u> M/R
	• Basements	<u>Nil</u>	<u>Nil</u>
	c. Protection of exits		
	• Fire check door		<u>N/R</u>
	• Pressurization		
	e. No. of continuous staircases to terrace		<u>1</u>
	g. Width of Corridor	<u>A</u>	<u>2 m</u>
	h. Door Size	<u>1 m</u>	<u>1.05m (Double doors)</u> M/R
3	Compartmentation.		
	• Fire check door		<u>N/R</u>
	• Sealing of electrical shafts		
	• Fire Rating of shaft door		
	• Water Curtain		
	• Fire Dampers		
4	Smoke Management System.		
	• Basements	30 a/c per hour	<u>N/A</u>
	• Upper floors	12 a/c per hour	<u>1</u>

5	Fire Extinguishers				
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	06 ABC ISI marked	06 ABC yes	MIR MIR MIR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	30 m 5 mm	NIR /		
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		NIR /		
8	MOEFA			NIR	
9	Public Address System.			NIR	
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		NIR /		
11	Internal Hydrants				
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		NIR /		
12	Yard Hydrants.				
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		NIR /		
13	Pumping Arrangements.				
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		NIR /		



14	Captive Water Storage for fire fighting.		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	Exit Signage.		
			NIR
16	Provision of Lifts.		
	• Pressurization of Lift Shaft		NIA
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	Standby power supply		
			NIR
18	Refuge Area.		
	➤ Total Area		NIA
	➤ Location		
19	Fire Control Room		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	Special Fire Protection Systems for Protection of special Risks, if any:		
		—	Nil —

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....



Signature of the Inspecting Officer

Name

Designation

*(Signature)*  
(N/A)  
*(Signature)*  
11/13

Signature of the Inspecting Officer 21/3/2013

Name

Designation

*(Signature)*  
SHYAM LAL  
Assist. Dirn. Officer