


No F 6 / DFS / MS / 2013 / 208

Dated 25/4/13

FIRE SAFETY CERTIFICATE

Certified that the NU. Delhi Restaurant located at 14/48, Malcha Marg, New Delhi – 110021, comprised of Basement + Ground + Mezzanine + 01 Upper floor (Basement is used for storage, Ground floor having seating arrangement+ Kitchen + bar counter, Mezzanine floor having seating arrangement, First floor is being used for office purpose having separate staircase) was granted NOC by this department vide letter No F6/DFS/MS/EH/09/ 3010 dated 13.10.2009. The premises was re- inspected by the officer concerned of this department on 09.04.2013 in the presence of Mr. Gopal Aggarwal (Manager) and found that the Restaurant have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Group D Assembly Building with effect from 25/4/13 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued 25/4/13 at New Delhi by.


(Dr. G.C. Misra)
Chief Fire Officer
Delhi Fire Service

Copy to: -

1. The Medical Officer of Health, New Delhi Municipal Council, Health Department, Licensing Unit, Palika Kendra, New Delhi.
2. Mr. Manjyot Singh (Partner) NU. Delhi Restaurant, at 14/48, Shopping Complex, Malcha Marg, New Delhi – 110021.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECITON REPORT

- 1) Name & address of the building: NU. Delhi Restaurant, 14/48, Malcha Marg, New Delhi - 21
- 2) Type of Occupancy : Assembly
- 3) Type of Case : Renewal
- 4) Details of previous NOC : Letter No F6/DFS/MS/EH/09/3010 Dated 13.10.2009
- 5) Fire Safety directives Letter No. : N/A
- 6) Date of inspection : 09.04.2013
- 7) Name of the Inspecting Officer : Dy. CFO Atul Garg
- 8) Name and designation of Officer
from the building side : Mr. Gopal Aggarwal (Manager)
- 9) Year of Construction : Before 2009
- 10) Applicant's letter No. : Nil Dated 01.03.2013.

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC/BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	N/A	09 mtr. (Approx.)	MR (Main Road)
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	02	MR (01 iron staircase rear side the bldg.)
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper floors	-----	01 mtr. & 0.80 mtr.	MR
	• Basements	-----	0.90 mtr. each	MR
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A



	d. No of continuous staircase to terrace	01	01	MR
	e. Width Of Corridor	N/A	N/A	N/A
	f. Door Size/Nos.	02	02	MR
3.	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/A	N/A
	• Upper floors	12 a/c per hour	Provided	MR (Exhaust Fan)
5.	Fire Extinguishers			
	• Total numbers	ISI marked	10	MR
	• Types		WT, CO ₂ ,	MR
	• IS marking		YES	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	01	01	MR
	• Length of hose reel hose	30 m	YES	MR
	• Nozzle diameter	5 mm	YES	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooters' Location	N/A	N/A	N/A
8.	MOEFA	YES	YES	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	• Basements	YES	YES	MR
	• Upper Floor	YES	YES	MR
	• Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	• Size of riser/down- comer	100 m	YES	MR
	• Number of hydrants per floor	01	YES	MR
	• Hose Box	01	YES	MR

Handwritten signature

12.	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Staring/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	450 Lpm/180 lpm	YES	MR
	➤ Head of the pump	30 mtr	YES	MR
	➤ Power supply	YES	YES	MR
	➤ Auto starting of pump	YES	YES	MR
14.	Captive water Storage for fire fighting			
	• Under ground tank capacity	N/A	N/A	N/A
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	5000 ltr.	5000 ltr.	MR
15	Exit Signage	YES	YES	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	N/A	N/A	N/A
	➤ Fireman's Grounding Switch	N/A	N/A	N/A
	➤ Lift Signage	N/A	N/A	N/A
17.	Standby power supply	YES	YES	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A

Old Case

	➤ Building Floor Plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for Protection of special Risks, if any;	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer



Name

Designation

Signature of the Inspecting Officer



Name

ATULGARS

Designation

DCPO