

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO. FG/DFS/MS/EH/2013/194

Dated: 23/04/13

FIRE SAFETY CERTIFICATE

Certified that **O₂ Multicuisine Restaurant** (name of the building or premises) located at **23-A(GF & FF), N N Tower, Block B, Road No. 44, DDA Commercial Complex, Pitampura, Delhi** was granted NOC by this department vide letter No. F.6/MS/DFS/EH/09/2973 dated 07-10-2009. The premises was re-inspected by the officer concerned of this department on 13-04-2013 in the presence of Mr. M.S. Rana, and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises / building is fit for occupancy **class D, Assembly** with effect from 23/04/13 for a period of **3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010** subject to conditions printed below.

Issued on 23/04/13 at New Delhi by.


(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Tel:- 011-23414250

E-mail:- cfowz.dlfire@nic.in

Copy to: -

1. The Addl.C.P (Lic.), 1st floor, Police Station Defence Colony, New Delhi.
2. The Owner, O₂ Multicuisine Restaurant, 23-A, NN Tower, Road No. 44, Pitampura, Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

- M/S -

3	Compartmentation.			
✓	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NR	NA	NA
	• Fire Rating of shaft door	NR	NA	NA
	• Water Curtain	NR	NA	NA
	• Fire Dampers	NR	NA	NA
4	Smoke Management System.			
✓	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Provided	MR
5	Fire Extinguishers			
	• Total numbers	06	Provided	MR
	• Types <i>CO₂ 4.5kg. & ABC-5kg.</i>	ISI marked	Provided	MR
	• IS marking		Provided	MR
6	First-Aid Hose Reels.			
✓	• Total numbers on each floor	one	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors			
	• Location of Main Panel			
	• Location of Repeater Panel			
	• Alternate source of power			
	• Hooters' Location			
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NA	NA
10	Automatic Sprinkler System.			
✓	• Basement	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR

✓	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 	One	Provided	MR
		One	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 			
	<ul style="list-style-type: none"> • Hose Box 		N/A	
13	Pumping Arrangements.			
✓	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 			
		450 LPM	Provided	MR
		36 mtr.	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		-	-	-
14	Captive Water Storage for fire fighting.			
✓	<ul style="list-style-type: none"> • Underground tank capacity <ul style="list-style-type: none"> ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NR	NA	NA
		NR	NA	NA
		NR	Provided	NA
		NR	NA	NA
		old case	5,000 lts.	old case.
15	Exit Signage.			
		Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft 			
	<ul style="list-style-type: none"> • Pressurization of Lift lobby 		N/A	

N/10

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 				
17	Standby power supply	Required	Provided (85KVA DG Set)	MR	
18	Refuge Area.				
	➤ Total Area				
	➤ Location				
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 				
20	Special Fire Protection Systems for Protection of special Risks, if any:	LPG Bank on Roof level	Fire Extinguishers and sprinkler point	MR	



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~

Signature of the Inspecting Officer
 Name S. K. Dua
 Designation ADO (WP)

Signature of the Inspecting Officer
 Name Sunil Chaudhary
 Designation DO (W)