

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F6/DFS/MS/School/2013/218

Dated: 26/04/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Pole Star School is comprised of Ground floor and two halls with 06 Class rooms located at Kh No 767, Karan Vihar, Opposite Sector-21, Rohini, Delhi-110086 owned and occupied by Pole star School, have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 04/2013 in the presence of Sh R.S.Khurana and that the building / premises is fit for occupancy of Group Class B (Educational) with effect from 26 / 04 /2013 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)

Issued on 26.04.13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
[cfowz.dlfire@nic.in](mailto:cfowz.dlfire@nic.in)

Copy to:

1. The Principal, Pole Star School, located at Kh No 767, Karan Vihar, Opposite Sector-21, Rohini, Delhi-110086
2. The Director of Education, Old Secretariat, Delhi



INSPECTION REPORT

1. Name & address of the building Pole Star school, Karan Vihar, Delhi-
2. Type of Occupancy Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No Circular, Dir. of Education. 13/11
6. Date of inspection 08/3/2013
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers  
from the building side : Sh. Jai Singh.
9. Year of Construction 2013, Groundonly 6 No Room & two enter connected
10. Applicant's letter No. one metre below hall with one exit each 3.33 m  
Nil dated 22-2-2013 ground level (Hall area approx 9.50 sq m)

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement <u>1/3/11</u>	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>Accessible</u>	<u>12</u>	<u>MR</u>
	• Gate width	<u>~</u>	<u>03.85 m</u>	<u>MR</u>
	• Width of internal road	<u>~</u>	<u>open ground</u>	<u>MR</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases		<u>NIA</u>	
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	<u>1 m</u>	<u>1 m (double door)</u>	<u>MR</u>
3	Compartmentation.			
	• Fire check door		<u>NIR</u>	
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
	• Basements	<u>30 a/c per hour</u>		
	• Upper floors	<u>12 a/c per hour</u>		



5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>06 ABC ISI marked</p>	<p>09 ABC yes</p>	<p>MIR MIR MIR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m 5 mm</p>	<p>NIR /</p>	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		<p>NIR /</p>	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		<p>NIR /</p>	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		<p>NIR /</p>	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		<p>NIR /</p>	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>		<p>NIR /</p>	

14	Captive Water Storage for fire fighting.		
	• Underground tank capacity		NIR
	➤ Draw-off connection		
	➤ Fire service inlet		
	➤ Access to tank		
	• Overhead Tank capacity		
15	Exit Signage.		
16	Provision of Lifts.		
	• Pressurization of Lift Shaft		NIA
	• Pressurization of Lift lobby		
	• Communication In lift Car		
	• Fireman's Grounding Switch		
	• Lift Signage		
17	Standby power supply		
18	Refuge Area.		
	➤ Total Area		NIA
	➤ Location		
19	Fire Control Room		
	• Detector System Panel		NIR
	• Flow Switch Panel		
	• PA System Panel		
	• Batter backup		
	• Building Floor Plans		
20	Special Fire Protection Systems for Protection of special Risks, if any:		
			NIR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name


Designation

DO (NW)  


Signature of the Inspecting Officer

Name

Designation

  
 13/3/2013  
 (SHYAM LAL)  
 Asstt. Dsm. Office.