

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001  
No. F6/DFS/MS/School/2013/228 Dated: 01/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the **R. G. Public** School located at **C -79, Aman Puri, Nazafgarh Road, Nangloi, Delhi** comprised of **Ground + one upper floor** occupied by **R. G. Public School** was issued NOC vide this office letter no. F.6/DFS/MS/09/2544 dated 17/08/2009. The premises was re-inspected by the officer concerned of this department on 13/03/2013 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated 17/01/2005 and the building/ premises is fit for occupancy Class **Educational** with effect from **01/05/2013** for a period of **three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010** subject to conditions printed below.

Issued on **01/05/13** at New Delhi.

  
29/5  
(SANTOKH SINGH)  
CHIEF FIRE OFFICER  
DELHI FIRE SERVICE  
Tel. No. - 011-23414250  
Email- cfosz.dlfire@nic.in

Copy to:

1. The Manager, R. G. Public School, C -79, Aman Puri, Nazafgarh Road, Nangloi, Delhi
2. The Director (Education), Govt. of NCT of Delhi, Old Sectt. Delhi.

**Following fire safety directives must be adhered to**

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

- MS -

INSPECTION REPORT

1. Name & address of the building : R.G. Public School C-79, Amanpuri, Naugla-  
(Nazafgarh Road)
2. Type of Occupancy : Educational (Gr. + one upper floor)
3. Type of Case : New Case/Renewal
4. Details of previous NOC : Letter No. F-6/DFC/MS/09/2544 Dated: 17/8/09
5. Fire Safety directives letter No. : -
6. Date of inspection : 13/03/2013
7. Name of the Inspecting Officers: ADO S.K. Dua
8. Name and designation of officers from the building side : Mr. Sanjay Garg, Manager
9. Year of Construction : 2004
10. Applicant's letter No. : DHO/RZ/2012/1021 dated 18/1/10

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06 mtr.	Provided	MR
	• Gate width	NR	3.8 mtr.	NA
	• Width of internal road	NR	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	old case NR	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NR	NA	NA
	• Pressurization	NR	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	g. Width of Corridor	1.5 mtr.	1.65 mtr.	MR
	h. Door Size	1.0 mtr.	1.1 mtr.	MR

M/s -

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			N/R
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour NA 12 a/c per hour	NA open to sky	NA MR
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	05 ISI marked	05 (Fire) / ABC-type, Provided	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	N/R 30 m 5 mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			N/R
8	<b>MOEFA</b>	NR	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>			N/R
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>	MR	NA	NA



- 1/8

	<ul style="list-style-type: none"> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>			
17	<b>Standby power supply</b>	NIR	NA	NA
18	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>		NIR	
19	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>			
20	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Signature of the Inspecting Officer

Name S. K. Dua

Designation ADD (WP)

Signature of the Inspecting Officer

Name

Designation