

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. FG/DFS/MS/School/2013/230

Dated: 01/05/2013

FIRE SAFETY CERTIFICATE

Certified that the **R.V. Convent School** (name of the building or premises) located at **65/25, Phase-IV, Tilang Pur Kotla, New Delhi – 110043** and comprised of Ground floor only, have complied with the fire prevention and fire safety requirements in accordance with Director of Education circular dated 01/03/2011 and verified by the officer concerned of Fire Service on 13/03/2013 in the presence of Miss Rajwati (Principal) and the building/premises is fit for occupancy **Educational** with effect from 01 / 05 /2013 for a period of **three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010** subject to conditions printed below.

Issued on 01/05/13 at New Delhi.



(SANTOKH SINGH)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Tel. No. - 011-23414250
Email- cfowz.dlfire@nic.in

Copy to:

The Principal, R.V. Convent School, 65/25, Phase – IV, Kotla Vihar, Delhi.

Following fire safety directives must be adhered to

1. All the Means of escape shall be kept free of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation with regards to construction, electrical installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **www.dfs.delhigovt.nic.in**

- N/A -

INSPECTION REPORT

1. Name & address of the building : R.V. Convent School, 65/25, Phase-IV, Kollavihar
2. Type of Occupancy : Educational (Ground floor only)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No :
6. Date of inspection : 13/02/2013
7. Name of the Inspecting Officers: ADO S.K. Dua
8. Name and designation of officers from the building side : Miss Smt. Rajwati
9. Year of Construction : March 2010
10. Applicant's letter No. : RVCS/01/2012-13 dated 12/11/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mtr.	Provided	MR
	• Gate width	-	on road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	N/A	NA	NA
	h. Door Size	1 mtr.	Provided	MR

- M2

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N/A open to sky	N/A MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 ISI marked	05 ABC 5 step Provided	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	N/A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA	NR	NA	NA
9	Public Address System.	NR	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 		N/A	
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NR	NA	NA

c. N/R-

	<ul style="list-style-type: none"> • Number of hydrants per floor • Hose Box 		N/A	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 		N/A	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		N/A	
			N/A	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N/A	
		NA	NA	NA
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby 		N/A	

- N/A -

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 				
17	Standby power supply				
18	Refuge Area.				
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 				
19	Fire Control Room				
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 				
20	Special Fire Protection Systems for Protection of special Risks, if any:	No			

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Name S. K. Dua

Designation ADO (w/p)

Signature of the Inspecting Officer

Name

Designation