

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

Ph - 23414333 Fax - 23412593 Email - cfohq.dfire@nic.in

No. F6/9 F-S/MS/Hospital/2013/284

Dated: 08/05/13

FIRE SAFETY CERTIFICATE

Certified that the Goyal Hospital & Urology Centre, E-4/8, Krishna Nagar, Delhi-51, comprised of Basement ground plus two upper floor owned/occupied by Goyal Hospital & Urology Centre, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officers concerned of Fire Service on dated 23.04.13 in the presence of Dr. Anil Goyal, Owner and that the building is fit for occupancy class C 'Institutional Building' with effect from ..08/05/13... for a period of **three** years, in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to conditions printed overleaf.

Issued on.....08/05/13.....at New Delhi by



(Dr. G.C. Misra)

Chief Fire Officer

Delhi Fire Service

To,

Dr. Anil Goyal

Goyal Hospital & Urology Centre, E-4/8, Krishna Nagar, Delhi-51

Copy to-

The Directorate of Health Services

M.O. I/C Nursing Home Cell,

Govt. of NCT of Delhi, F-17, Karkardooma, Delhi-32.



CONDITIONS:

1. All the means of escape shall be kept free of all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This Fire Safety Certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
7. Basement shall be used as per BBL.

INSPECTION REPORT

1. Name & address of the building : Goyal Hospital & Urology Centre, E-4/8, Krishna Nagar, Delhi-51.
 2. Building is comprised of : B+G+2
 3. Type of Occupancy : Institutional Building
 4. Type of Case : New Case
 5. Details of Previous NOC : Nil
 6. Fire Safety direction letter No : Delhi Fire Service Act, 2007 and Rules 2010.
 7. Date of Inspection : 23.04.13
 8. Name of the Inspecting Officers: : Suresh singh (ADO)
 9. Name of the designation of Officer
 from the building side : Dr. Anil Goyal
 10. Year of Construction : 2001/2009
 11. Applicant's letter No : Dated 25.02.13

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	15 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	3 no.	3 no.	MR
	Upper Floor	2 no.	2 no.	MR
	Basement	2 no.	2 no.	MR
	B. Width of Staircases	2 m	2 m, 1 m, 1.2 m	MR ✓
	Upper Floor	1 m, 1.2 m	MR
	Basement	1 m	MR
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace	02 no.	02 no.	MR
	g. Width of Corridor
h. Door Size	1 m, 2 m	1 m, 2 m	MR	
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	Ventilated		
	Basement	30a/c per hour	Ventilated	MR
	Upper floor	12 a/c per hour	Ventilated	MR

		Required	Provided	
5.	Fire Extinguisher			
	Total numbers	20 no.	20 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.			
	Total numbers of each floor	02 no.	02 no.	MR
	Length of hose reel hose	30 m	30 m	MR
	Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.			
	Type of detectors	Smoke & Heat	Smoke & Heat	MR
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes	Provided	MR
9	Public address System.	Yes	Provided	MR
10	Automatic Sprinkler System.			
	basement	Required	Provided	MR
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants			
	size of riser/down-comer	100 mm	100 mm	MR
	Number of hydrants per floor	2 no.	2 no.	MR
	Hose Box	2 no.	2 no.	MR
12	Yard Hydrants.			
	Total number of hydrants	1 no.	1 no.	MR
	Hose Box	1 no.	1 no.	MR
13	Pumping Arrangements.	Required	Provided	
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump	1620 LPM	1620 LPM	MR
	➤ Head of the Pump	60 m	60 m	MR
	➤ Power supply
	➤ Auto Starting of pump

IRN/5

Goyal Hospital & Urology Centre, E-4/8, Krishna Nagar, Delhi-51.

14	Captive Water Storage for Fire Fighting.	Required	Provided	
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity	50,000 Liters	50,000 Liters	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	Yes	Provided	
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	Yes
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

S Singh

Signature of the Inspecting Officer

Name Suresh Singh

Designation A.D.O

