

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2013/ *School/282*

Dated: *08/05/13*

FIRE SAFETY CERTIFICATE

Certified that the – **Multan DAV Sec. School, Old Rajinder Nagar, New Delhi-110060** Comprised of –ground floor plus one upper floors and owned/occupied by Multan DAV Sec. School has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 25.04.13 in the presence of Sh. J.K. Sharma In-charge and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on .....*08/05/13*.....at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Vice Principal,  
Multan DAV Sec School,  
Old Rajinder Nagar  
New Delhi-110060.
2. The Director of Education  
Govt. of NCT of Delhi  
Old Secretariat, Delhi.

*o/c*  
*Me*

**INSPECTION REPORT**

1. Name & address of the building : Multan DAV Sec. School, Old Rajender Nagar MD
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIL Dated: -
5. Fire Safety directives letter No : F 6/DR3/MR/07/2622 dt 18/9/07
6. Date of inspection : 25/04/13
7. Name of the Inspecting Officers : SH. H.C. ANEJA - Dir. Officer
8. Name and designation of officers from the building side : Sh. J. K. Sharma. Incharge (Teacher)
9. Year of Construction : -
10. Applicant's letter No. : M.DAV/2013/025 dt 18/2/13.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	R	9 mtrs	MR
	• Gate width	R	2.82 mtrs	MR
	• Width of internal road	R	12 mtrs	MR
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	b. Width of staircases	R	155 cms & 88 cms	MR
	• Upper Floors	—	—	—
	• Basements	NIL	—	—
	c. Protection of exits	NR	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	one	MR
	g. Width of Corridor	R	2.15 mtr	MR
	h. Door Size	R	112 cms	MR



3	<b>Compartmentation.</b>				
	• Fire check door	NR	—	—	—
	• Sealing of electrical shafts	—	—	—	—
	• Fire Rating of shaft door	—	—	—	—
	• Water Curtain	—	—	—	—
	• Fire Dampers	—	—	—	—
4	<b>Smoke Management System.</b>				
	• Basements	NR	—	—	—
	• Upper floors	30 a/c per hour 12 a/c per hour	—	—	—
5	<b>Fire Extinguishers</b>				
	• Total numbers	R	P	NR	—
	• Types		6 Nos	—	—
	• IS marking	ISI marked	DCP type Yes	—	—
6	<b>First-Aid Hose Reels.</b>				
	• Total numbers on each floor	NR	—	—	—
	• Length of hose reel hose	30 m	—	—	—
	• Nozzle diameter	5 mm	—	—	—
7	<b>Automatic fire detection and alarming system.</b>				
	• Type of detectors	NR	—	—	—
	• Location of Main Panel	—	—	—	—
	• Location of Repeater Panel	—	—	—	—
	• Alternate source of power	—	—	—	—
	• Hooters' Location	—	—	—	—
8	<b>MOEFA</b>				
		NR	—	—	—
9	<b>Public Address System.</b>				
		—	—	—	—
10	<b>Automatic Sprinkler System.</b>				
	• Basement	—	—	—	—



	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>				
11	<b>Internal Hydrants</b>	NR			
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>				
12	<b>Yard Hydrants.</b>	NR			
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>				
13	<b>Pumping Arrangements.</b>	NR			
	<ul style="list-style-type: none"> <li>• Ground Level                             <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level                             <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>				
14	<b>Captive Water Storage for fire fighting.</b>	NR			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>				



1	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
		—	—	—
		—	—	—
15	Exit Signage.	NR	—	—
16	Provision of Lifts.	NR	—	—
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19	Fire Control Room	NR	—	—
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
		—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~..... Nil

Signature of the Inspecting Officer

*[Handwritten Signature]*

Name H. L. ANETA

Designation Div Officer

Signature of the Inspecting Officer

Name

Designation

5