

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/2013 /239

Dated: 02/05/2013

FIRE SAFETY CERTIFICATE

Certified that the SHANTI ROYAL BANQUETS, B-4 G.TK ROAD, IND. AREA DELHI 110033. Comprised of Basement, Ground, First & 2nd Floor, owned/occupied by Shanti Royal Banquets (A unit of S.A Fragrances PVT. LMT) have complied with fire prevention and fire safety requirement in accordance with rule 33 of the Delhi Fire Service Rule 2010 and verified by the officer concerned of fire service on 09/04/13.in the presence of Mr. Himanshu (Manager) and that the building /premises is fit for occupancy Assembly building with effect from ..02/05/13...for period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Conditions for the validity of Fire Safety Certificate:

- 1 All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
- 2 Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
- 5 The basement shall be used strictly as per the provision of building bye laws.
- 6 This certificate cannot be treated in any case for regularizations of unauthorized construction
- 7 The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on...02/05/2013 at New Delhi.


(SANTOKH SINGH)
Chief Fire Officer
Delhi Fire Service
Ph: 011-23414250
cfowz.dlfire@nic.in

Copy to:

1. The Dy. Health Officer, Civil line Zone, North Delhi Municipal Corporation, 16, Raj pur Road, Delhi.
2. Shanti Royal Banquets B-4, G.T.K Road Ind. Area Delhi 110033.

N/20
Re-inspection to verify Compliance of Short Comings.

INSPECTION REPORT

1. Name & address of the building : SHANTI ROYAL BANQUETS, B-4 S.T.K Rd. Ind. Area Delhi 110033
2. Type of Occupancy : Banquet Hall (Assembly)
3. Type of Case : New Case/ Renewal for Assembly Bldg.
4. Details of previous NOC : Letter No. Dated:
5. Fire Safety directives letter No : F-6/DFS/MS/2012/BP/3553 dt. 26/9/12
6. Date of inspection :
7. Name of the Inspecting Officers : Deto vijin kental & J.O S.S. Tuli
8. Name and designation of officers:
from the building side :
9. Year of Construction : 2012
10. Applicant's letter No. : nil dt. 21-3-13

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width			
	• Gate width			
	• Width of internal road			
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
✓	• Fire check door	R	P	M/R -
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
✓	h. Door Size	02 Mtr.	P	M/R -
3	Compartmentation.			
✓	• Fire check door	R	P	M/R -
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	Smoke Management System.			
✓	• Basements	30 a/c per hour	P	M/R -
✓	• Upper floors	12 a/c per hour	P	M/R -

M/21

5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 nos of W. Co2 08 nos of DCP/62 ISI marked type	P	M/R
			Yes	M/R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	2 nos 30 m 5 mm	P P P	M/R M/R M/R
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 			
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	2 nos	P	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	4 nos 2280 lpm 40 mtr	P P P	M/R M/R M/R

N/22

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity 	50000	P	M/R
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity			
15	Exit Signage.	R	P	M/R
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 			
17	Standby power supply			
18	Refuge Area.			
	➤ Total Area			
	➤ Location			
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 			
20	Special Fire Protection Systems for Protection of special Risks, if any:	Separate circuit for emergency service	P	M/R



The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation