

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. FG 1DRS/MS/80hcd/2013/267

Dated: 07/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the Shri Guru Nanak Public School, Adarsh Nagar, Delhi. is comprised of Basement + Ground + Three Upper Floors owned and occupied by Gurudwara Shri Guru Singh Sabha, have complied with the fire prevention and fire safety requirements in accordance with Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 17/04/2013 in the presence of Sh. Dhiren M. Doshi and that the building / premises is fit for occupancy of (Educational) with effect from 07/05/2013 for a period of three years, subject to compliance of the conditions.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 07/05/13 at New Delhi by

  
(SANTOKH SINGH)  
Chief Fire Officer  
Delhi Fire Service  
Ph: 011-23414250  
cfowz.dlfire@nic.in

**Copy to:**

1. The Principal, Shri Guru Nanak Public School, Adarsh Nagar, Delhi
2. The Director of Education, Old Secretariat, Delhi 110054.



INSPECTION REPORT

1. Name & address of the building Shri Guru Nanak Public School, Adash Nagar - Delhi
2. Type of Occupancy Educational
3. Type of Case New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No Circular, Director of Edn.
6. Date of inspection 17-4-2013
7. Name of the Inspecting Officers : ADO-SHYAM LAL
8. Name and designation of officers from the building side Sh. Dhiren M. Doshi
9. Year of Construction 1978, (Gr. + 3) ✓
10. Applicant's letter No. \_\_\_\_\_

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Provided at site	Remarks MR/NMR
1	Access to building		
	• Road width	Accessible 6 m	MIR
	• Gate width	- - - 4.01 m	MIR
	• Width of internal road	N/A N/A	N/A
2	Number, Width, Type & Arrangement of Exits		
	a. Number of staircases	4	4
	• Upper Floors	4	4
	• Basements	Nil	Nil
	b. Width of staircases		
	• Upper Floors	1.5 m	1.2 m each
	• Basements	Nil	Nil
	c. Protection of exits		
	• Fire check door		NIR
	• Pressurization		/
	e. No. of continuous staircases to terrace		/
	g. Width of Corridor	R	1.4 m
	h. Door Size	1 m	95 cm
3	Compartmentation.		(Two doors)
	• Fire check door		NIR
	• Sealing of electrical shafts		/
	• Fire Rating of shaft door		/
	• Water Curtain		/
	• Fire Dampers		/
4	Smoke Management System.		
	• Basements	30 a/c per hour	NIR
	• Upper floors	12 a/c per hour	/

*Building (old case) ✓*



5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	19 ABC ISI marked	Provided	MIR ✓
			Provided	MIR
			Provided	MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	Two 30 m 5 mm	Provided	MIR ✓
			Provided	MIR ✓
			Provided	MIR ✓
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		NIR	
8	MOEFA		NIR	
9	Public Address System.		NIR	
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		NIR	
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		NIR	
12	Yard Hydrants..			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		NIR	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>		NIR	
		900 Lts/min	Provided	MIR ✓
		40 m	—	MIR ✓
		NIR	NIR	N/A
		R	Provided	MIR ✓

14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>		NIR	
		10000 Lts	18000 Lts.	MIR
15	Exit Signage.	R	P	MIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>		NIA	
17	Standby power supply			NIR
18	Refuge Area.			
	➤ Total Area		NIA	
	➤ Location		/	
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	—	Nil	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer

Signature of the Inspecting Officer

Name

Name

Designation

Designation

D.O. (NW)

SHYAM LAL

Assist. Divn. officer

*P. Shylal*  
20/11/2013

*Shylal*  
20/11/13