

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfhq.dlfire@nic.in


No *FD/DFS/MS/School/2013/247*

Dated *03/05/13*

FIRE SAFETY CERTIFICATE

Certified that the St. Moral Global School C-6, D.D.A. Market, Yamuna Vihar, Delhi, comprises of basement, ground & two upper floors with 26 rooms have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 17-4-2013 in the presence of Principal. and that the premises is fit for occupancy of "Educational Building" with effect from *03-05-2013* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on *03/05/2013* at New Delhi.


(DR. G.C.MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. 23414333

Copy to:-

1. The Principal
St. Moral Global School
C-6, D.D.A. Market, Yamuna Vihar,
Delhi - 110053.
2. The Director Education,
Government of N.C.T Delhi.
Old Sectt, Delhi 110054

92

hm
21/5/13

Condition

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments, shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basements shall be used as per BBL
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

-N/1-

INSPECTION REPORT

- 1. Name & address of the building: St. Moral Global School C-6,
D.D.A.Market, Yamuna Vihar, Delhi
- 2. Building is comprised of : Basement, Ground & two floors
- 3. Type of Occupancy : Educational.
- 4. Type of Case : New Case
- 5. Details of Previous NOC letter: NA
- 6. Fire Safety direction letter No : NA
- 7. Date of Inspection : 05-04-2013
- 8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
- 9. Name and designation of Officer: Principal
from the building side
- 10. Year of Construction : 2011
- 11. Applicant's letter No : SMGS/127 dated 27-02-2013

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement.	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	30 ft	MR
	• Gate width	Accessible	MR
	• Width of internal road	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2Nos.	2Nos.	MR
	• Basement	2nos	2nos	MR
	B. Width of Staircases
	• Upper Floor	02Nos.	1.5Mtr. & .90Mtr	MR
	• Basement	2 Nos	1.5Mtr & .90Mtr	MR
	c. Protection of exits	-----	-----	-----
	• Fire check door	NA	NA	NA
	• Pressurization	-----	-----	-----
	e. No. of continuous staircases to terrace	02	2Nos.	MR

- 11/2 -

	g. Width of Corridor h. Door Size	1.0Mtr	1.0mtr	MR
3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 			
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper floor 			
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types • IS marking 	9 Nos. ABC&CO2 Required	9 Nos. ABC& CO2 Provided	MR MR MR
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers at ground floor • Length of hose reel hose • Nozzle diameter 	1No each floor 30Mtr. 5mm	1No each floor 30Mtr. 5mm	MR MR MR
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power Required Provided MR
	Hooter's location			
8	MOEFA	NR	MR
9	Public address System.	NA	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • upper floor • sprinkler above false ceiling 	NR	Provided in basement	MR MR
11	Internal Hydrants	NR	Provided	MR
	<ul style="list-style-type: none"> • size of riser/down-comer • Number of hydrants per floor • Hose Box 	NR NR	100mm 1No	MR MR
12	Yard Hydrants.	NA	NA	NA
	<ul style="list-style-type: none"> • Total number of hydrants 	

A/3

St. Moral Global School,
C-6, DDA Market, Yamuna Vihar
Delhi

13	<ul style="list-style-type: none"> Hose Box Pumping Arrangements.	MR
	<ul style="list-style-type: none"> Ground Level 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Head of Main Pump 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Number of main pumps 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Jockey pump out put 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Jockey pump head 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Standby pump out put 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Standby pump Head 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Auto Starting /Manual stopping 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Pump House Access 	-----	-----	-----
	<ul style="list-style-type: none"> Terrace Level 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Discharge of pump 	450LPM	450LPM	MR
	<ul style="list-style-type: none"> ➤ Head of the Pump 	40Mtr	40 Mtr	MR
	<ul style="list-style-type: none"> ➤ Power supply 	Required	Provided	MR
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	<ul style="list-style-type: none"> Underground tank capacity 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Draw-off connection 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Fire service inlet 	-----	-----	-----
	<ul style="list-style-type: none"> ➤ Access to tank 	-----	-----	-----
	<ul style="list-style-type: none"> Overhead Tank capacity 	10,000Ltr.	15,000Ltr.	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA	NA	NA
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	-----	-----	-----
	<ul style="list-style-type: none"> Pressurization of Lift-lobby 	-----	-----	-----
	<ul style="list-style-type: none"> Communication in lift car 	-----	-----	-----
	<ul style="list-style-type: none"> Firemen's grounding switch 	-----	-----	-----
	<ul style="list-style-type: none"> Lift Signage 	-----	-----	-----
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	<ul style="list-style-type: none"> Total area 	-----	-----	-----
	<ul style="list-style-type: none"> Location 	-----	-----	-----
19	Fire Control Room	NA	NA	NA
	<ul style="list-style-type: none"> Detector system panel 	-----	-----	-----
	<ul style="list-style-type: none"> Flow switch panel 	-----	-----	-----

20/11-1

	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Gurpreet Singh
20/11/13

Name Gurpreet Singh

Designation ADO(LN)