

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110 001  
Fax: 23412593, E-mail: cfohq.dlfire@nic.in

No. F61 DFS/MS/ FW/2013/817

Dated 15/05/2013

**FIRE SAFETY CERTIFICATE**

Certified that the M/S Hanuman Fireworks Prop. Smt. Anita Gupta at Plot no.1, Ground floor, Shop no. 1, Gali no.1, Khasra no.550, Vill-Karkardooma, Arya Nagar, Vikas Marg, Delhi-92, comprised of ground plus one upper floor owned/occupied by M/S Hanuman Fireworks have complied with the fire prevention and fire safety requirements in accordance with the Delhi Police Act and verified by the officer concerned of Fire Service on dated 16.04.13 in the presence of Sh.Vinod Gupta and that the shop no.1, is fit for occupancy class Fireworks storage with effect from.....15/05/13.....for a period of three years, subject to conditions printed overleaf.

Issued on.....15/05/2013.....at New Delhi by

  
(Dr.G.C.Misra)  
Chief Fire Officer  
Delhi Fire Service  
Ph.23414333

To,  
The Additional Commissioner of police (Licensing),  
1<sup>st</sup> Floor, P.S. Defence colony, New Delhi.

Copy to:-  
Smt Anita Gupta w/o Sh.Vinod Gupta,  
H.no.221, 1<sup>st</sup> Floor, Dayanand Vihar,  
Shakar Pur, Delhi -92.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention and safety measures provided in the

IRN-1

### INSPECTION REPORT

1. Name & address of the building : M/s Hanuman Fireworks at Plot no.1 Shop no. 1,Gali no.1,Khasra no.550, Vill-Karkardooma, Arya Nagar, Vikas Marg, Delhi-92.
2. Type of Occupancy : Storage Fireworks
3. Type of Case : New Case
4. Details of Previous NOC : Nil
5. Fire Safety direction letter No : -----
6. Date of Inspection : 16.04.2013
7. Name of the Inspecting Officers : ADO Suresh Singh
8. Name of the Person from the : Mr. Vinod Gupta  
Building side
9. Year of Construction : 2005
10. Reference/Licensing deptt. letter no. (PFW/08)/2013/13691 - 93/Addl.Cp/Lic.(Expl.) dated 28.03.13

S.NO.	Point of Inspection	Requirement	At Site	Remarks MR/NMR
1	Type of construction and floor area & floor level			
	a. Minimum floor area	9m2 (Min.)	15 m2	MR
	b. Construction	Pucca	Provided	MR
	C. Premises Location	Not under the staircase/Mean of escape	Provided	MR
	d. Business permissible only at ground floor level	Required	Provided	MR
	e. Business from pavement of road prohibited	prohibited	Yes	MR
2	Entrance & Exits to the licensed premises			
	The licensed premises shall have independent entrance and exit	Required	Provided (Yes)	MR

IRN-2

3	Type and distance of the surrounding risk			
	The premises shall be situated at a distance of 15 m from any such premises used for similar explosives/ inflammable or hazardous materials.	Required 15 m	Provided	MR
4	Nature of business run in the licensed premises			
	The premises in which fireworks are kept shall be used only for possession and sale for fireworks and no other purposes.	Required	Provided (yes)	MR
5.	Type of electrical wiring and electrical fittings			
	a. Preferably concealed or through conduit	Required	Provided	MR
	b. All electrical fitting should be flame/spark proof	Required	Provided with casing & capping	MR
6	Extension of Shop for Business.			
	Prohibited	Prohibited	Yes	MR
7	Approach Road			
	The road width on the side of which premises is located should be 12m.	12 M	30 M	MR
8	Fire Protection Arrangement.			
	a) Extinguishers (Type & No's.)	2 nos. water type & 1 no. of ABC/Co2 type	Provided	MR
	b) Sand and Water Buckets	2 nos. each	Provided	MR
	c) Water Drum(s)	1 nos.	Provided	MR
9	Any other point that is contrary to the safety of people.			

The fire protection systems provided in shop were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

*Singh*

Signature of the Inspecting Officer

Name: SURESH SINGH

DO/CR