

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001
Fax: 23412593 E-mail:cfhq.dlfire@nic.in

No. *FG/DFSI MS/BANQUET/2013/294* Dated *14/05/2013*

FIRE SAFETY CERTIFICATE

Certified that the M/s J. R. P. Vatika C-24-25, Acharya Nikatan Mayur Vihar Ph-1, Delhi at first floor and second floor of the building which comprises of ground, mezz & two upper floors, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 04-05-2013 in the presence of Mr. Surinder Singh Gulati and that the premises is fit for occupancy of Assembly (Banquet Hall) at first & second floor only with effect from *14-5-* 2013 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on *14.05.13* at New Delhi.



(DR G.C.MISRA)
CHIEF FIRE OFFICER
DELHI FIRE SERVICE
Ph. 23414333

Copy to:

1. M/s J. R. P. Vatika C-24-25,
Acharya Nikatan Mayur Vihar Ph-1,
Delhi - 110092
2. The Dy. Health Officer,
East Delhi Health Department,
Shahdara (South) Zone, Karkardooma,
Shahdara, Delhi.

DC
13-5-13

Condition

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

- 2721 -

INSPECTION REPORT

1. Name & address of the building: M/S J. R. P. Vatika C-24-25,
Acharya Niketan Mayur Vihar Ph –
1, Delhi – 110092.
2. Building is comprised of : Ground, mezz & two upper floors
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Fresh
5. Details of Previous NOC : NA
6. Fire Safety direction letter No : F6/DFS/MS/BP/2013/39 dated 3.1.13
7. Date of Inspection : 4.5.2013
8. Name of the Inspecting officers: DO (E) & ADO (Laxmi Nagar)
9. Name and designation of Officer:
from the building side : -Mr. Surinder Singh Gulati.
10. Year of Construction : 1999
11. Applicant's letter No : - Nil - dated 5.3.2013

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 Mtr	13.5 Mtr	MR
	• Gate width	Directly accessible from road
	• Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2Nos	2Nos	MR
	• Upper Floor	2Nos	2Nos	MR
	• Basement	NA	NA	NA
	B. Width of Staircases			
	• Upper Floor	1.5 Mtr	1.5& 1.4Mtrs	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire-check door	Required	Provided	MR

	<ul style="list-style-type: none"> • Pressurization 	NA	NA	NA
	e. No. of continuous staircases to terrace	2 Nos.	2 Nos.	MR
	g. Width of Corridor
	h. Door Size	2 Mtr	2 Mtr	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	NA	NA	NA
	• Water curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basement	NA	NA	NA
	• Upper floor	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	4 nos.	12 nos.	MR
	• types	ABC & Co2	ABC & Co2	MR
	• IS marking	Required	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers at ground floor	1 No	1No	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	NA	NA	NA
	• Location of main panel	NA	NA	NA
	• Location of repeater panel	NA	NA	NA
	• Alternate source of power	Reqd.	Provided	MR
	• Hooter's location	Near Gate	Near Gate	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NA	NA	NA
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• upper floor	NA	NA	NA
	• sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• size of riser/down-comer	100mm	100mm	MR
	• Number of hydrants per	1 No	1 No	MR

- 17/6 -

JRP Vadikra, e-24-25,
Acharya Niketan,

	floor			
	• Hose Box	1 No	1 No	MR
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	Required	Provided	MR
	➤ Discharge of pump	450LPM	450 LPM	MR
	➤ Head of the Pump	40 Mtr	40 Mtr	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	15000 Ltr	15,000 Ltr	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.	NA	Provided	
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	Provided	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room			

-14/7-

	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.



DC(E)

Signature of the Inspecting Officer

Name

Designation

Gurpreet Singh
8/5/13
GURPREET SINGH
ADDON